



**Cyfoeth
Naturiol
Cymru
Natural
Resources
Wales**

Ein cyf/Our ref: CAS-215642-J2W6
Eich cyf/Your ref: P/23/0096

Rivers House,
St Mellons Business Park,
St Mellons,
Cardiff,
CF3 0EY

Merthyr Tydfil County Borough
Council,
Unit 5 Traingle Business Park,
Pentrebach,
Merthyr Tydfil,
CF48 4TQ

ebost/email:
southeastplanning@cyfoethnaturiolcymru.gov.uk
Symudol / Mobile: 07971 847091
Ffôn/Phone: 03000 654959

21/04/2023

Annwyl Syr/Madam / Dear Sir/Madam,

BWRIAD / PROPOSAL: CHANGE OF USE TO TATTOO PARLOUR (SUI GENERIS).

LLEOLIAD / LOCATION: 19 PONTMORLAIS, HIGH STREET, MERTHYR TYDFIL, CF47 8UB.

Thank you for consulting Cyfoeth Naturiol Cymru / Natural Resources Wales about the above, which we received on 18 April 2023.

We have no objection to the proposed development as submitted and provide the following advice.

Flood Risk

Our Flood Risk Map confirms the application site lies entirely within Zone C2 of the Development Advice Maps (DAM) as contained in Technical Advice Note (TAN) 15: Development and Flood Risk (2004). The Flood Map for Planning identifies the application site to be at risk of flooding and falls into Flood Zone 3 Rivers.

Given the nature of the proposed development (change of use from retail and residential to sui generis without any overnight residential accommodation) (and in the absence of a flood consequences assessment) we consider the proposals could be acceptable, subject to the developer being made aware of the potential flood risks and advised to install flood-proofing measures as part of the development.

In areas at risk of flooding, we recommend that consideration be given to the incorporation of flood resistance/resilience measures into the design and construction of the development. These could include flood barriers on ground floor doors, windows and access points, implementation of suitable flood proofing measures to the internal fabric of the ground floor and locating electrical sockets/components at a higher level above possible flood levels.

Advice to Applicant

We refer the applicant to our [website](#) for further advice and guidance is available. Additional guidance including the leaflet “Prepare your Property for flooding” can be found [here](#).

The developer can also access advice and information on protection from flooding from the ODPM publication ‘Preparing for Floods: Interim Guidance for Improving the Flood Resistance of Domestic and Small Business Properties’, can be found [here](#).

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

Advice for the Developer

Pollution Prevention

The building to be converted is adjacent to Nant Morlais. Due to the proximity of the site to this watercourse, any works required for the proposal must be carried out in accordance with Guidance for Pollution Prevention 5: Works and maintenance in or near water, which is available on the NetRegs website.

If you have any queries on the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully

Kate Glover

Cynghorydd - Cynllunio Datblygu / Advisor - Development Planning
Cyfoeth Naturiol Cymru / Natural Resources Wales