

12421/RH

17 February 2020

NHBC Building Control Services
NHBC House
Davy Avenue
Knowlhill
Milton Keynes
MK5 8FP

For the attention of Miss Emma Jones

Dear Sirs,

**Former Merthyr Vale Colliery, Golwg Yr Afon, Merthyr Vale, Merthyr Tydfil, CF48 4ST
NHBC Job Ref: 211366: Plot 61 to 63 and 65 to 72.**

We write on behalf of our client Lovell Partnerships (South Wales) with regard to the above site and the most recent NHBC Engineering Schedule of Outstanding Conditions:

LQ Conditions Condition 2 and 3

Plots 61 to 63 and 65 to 72 have recently been inspected on the 4th February 2020 in accordance with the remediation strategy for the site and found to have the required total of 600mm of clean cover soils placed over a geotextile membrane in garden areas, see attached photographs.

Photographs of capping depth in Appendix A.

Samples of the 'as placed' topsoil and subsoil soil materials in the above garden area of plot 61, 63 and 68 have been sampled and sent to the accredited laboratories of i2 Analytical for chemical analysis. The results are now available and attached with this report all contaminants of concern have been found to be below all threshold limits.

This report therefore confirms that the garden capping soils that have been inspected and tested are deemed suitable for their intended end use with respect to the protection of human health.


Chemical soil test reports attached in Appendix B.

The results of the topsoil and subsoils sampled from within plots above have been summarised and compared to the appropriate screening criteria for a residential end use. The results have been compared to appropriate Category 4 Screening Levels (C4SL) in the first instance. In their absence, the results will have been compared to the Suitable 4 Use Levels (S4ULs) derived by LQM, Soil Guideline Values (SGVs) and Soil Screening Values (SSVs) derived by Atkins ATRISKsoil for residential with the consumption of home grown produce end use, to assess the potential risk to human health.

Summary of chemical testing results attached in Appendix C.

We trust that the above is to your satisfaction. However, if you have any queries or require any further information, please do not hesitate to contact us.

Yours faithfully,

A handwritten signature in black ink, appearing to read 'R. Hawkins', with a long horizontal flourish extending to the right.

Roger Hawkins

For

Intégral Géotechnique (Wales) Limited

c.c. Shane Jay Lovell Partnerships Limited (South Wales)

Encs.

APPENDIX A

FIGURES



Plot 61 Showing Capping Depth



Plot 61 Excavation Pit with Membrane at Base of Soils

Garden Capping Validation.

Plot 61

Intégral
Géotechnique

Integral House
Castlegate Business Park
Caerphilly
CF83 2AX
Tel: 029 20807991
Fax: 029 20862176



Plot 61 Showing Trial Pit Profile



Plot 63 Capping Depth Check

Garden Capping Validation.

Plot 61 & 63

Intégral
Géotechnique

Integral House
Castlegate Business Park
Caerphilly
CF83 2AX
Tel: 029 20807991
Fax: 029 20862176



Plot 64 Excavation Pit with Membrane at Base of Soils



Plot 63 Showing Trial Pit Profile

Garden Capping Validation.

Plot

Intégral
Géotechnique

Integral House
Castlegate Business Park
Caerphilly
CF83 2AX
Tel: 029 20807991
Fax: 029 20862176



Plot 68 Showing Capping Depth



Plot 68 Excavation Pit with Membrane at Base of Soils (water Ingress)

Garden Capping Validation.

Plot 68

Intégral
Géotechnique

Integral House
Castlegate Business Park
Caerphilly
CF83 2AX
Tel: 029 20807991
Fax: 029 20862176

APPENDIX B

SOIL TEST RESULTS



Roger Hawkins

Integral Geotechnique
Integral House
7 Beddau Way
Castlegate Business Park
CF83 2AX

t: 02920807991
f: 02920862176
e: roger@integralgeotec.com



i2 Analytical Ltd.
7 Woodshots Meadow,
Croxley Green
Business Park,
Watford,
Herts,
WD18 8YS

t: 01923 225404
f: 01923 237404
e: reception@i2analytical.com

Analytical Report Number : 20-85054

Project / Site name:	Riverside Merthyr	Samples received on:	06/02/2020
Your job number:	12421	Samples instructed on:	06/02/2020
Your order number:		Analysis completed by:	14/02/2020
Report Issue Number:	1	Report issued on:	14/02/2020
Samples Analysed:	6 soil samples		

Signed: 

Zina Abdul Razzak
Senior Quality Specialist

For & on behalf of i2 Analytical Ltd.

Standard Geotechnical, Asbestos and Chemical Testing Laboratory located at: ul. Pionierów 39, 41 -711 Ruda Śląska, Poland.

Accredited tests are defined within the report, opinions and interpretations expressed herein are outside the scope of accreditation.

Standard sample disposal times, unless otherwise agreed with the laboratory, are :

soils	- 4 weeks from reporting
leachates	- 2 weeks from reporting
waters	- 2 weeks from reporting
asbestos	- 6 months from reporting

Excel copies of reports are only valid when accompanied by this PDF certificate.

Any assessments of compliance with specifications are based on actual analytical results with no contribution from uncertainty of measurement. Application of uncertainty of measurement would provide a range within which the true result lies. An estimate of measurement uncertainty can be provided on request.

Iss No 20-85054-1 Riverside Merthyr 12421

This certificate should not be reproduced, except in full, without the express permission of the laboratory.
The results included within the report are representative of the samples submitted for analysis.

Page 1 of 8

Analytical Report Number: 20-85054

Project / Site name: Riverside Merthyr

Lab Sample Number				1433047	1433048	1433049	1433050	1433051
Sample Reference				Plot 61 Topsoil	Plot 61 Subsoil	Plot 63 Topsoil	Plot 63 Subsoil	Plot 68 Topsoil
Sample Number				None Supplied	None Supplied	None Supplied	None Supplied	None Supplied
Depth (m)				0.10	0.40	0.10	0.40	0.10
Date Sampled				04/02/2020	04/02/2020	04/02/2020	04/02/2020	04/02/2020
Time Taken				None Supplied	None Supplied	None Supplied	None Supplied	None Supplied
Analytical Parameter (Soil Analysis)	Units	Limit of detection	Accreditation Status					
Stone Content	%	0.1	NONE	< 0.1	< 0.1	< 0.1	< 0.1	< 0.1
Moisture Content	%	N/A	NONE	23	23	30	10	29
Total mass of sample received	kg	0.001	NONE	0.51	0.55	0.50	0.54	0.51

Asbestos in Soil	Type	N/A	ISO 17025	Not-detected	Not-detected	Not-detected	Not-detected	Not-detected
------------------	------	-----	-----------	--------------	--------------	--------------	--------------	--------------

General Inorganics

pH - Automated	pH Units	N/A	MCERTS	7.4	8.7	7.3	7.6	7.4
Total Cyanide	mg/kg	1	MCERTS	< 1	< 1	< 1	< 1	< 1
Total Sulphate as SO ₄	mg/kg	50	MCERTS	650	1100	870	180	920
Water Soluble SO ₄ 16hr extraction (2:1 Leachate Equivalent)	g/l	0.00125	MCERTS	0.031	0.19	0.041	0.015	0.042
Sulphide	mg/kg	1	MCERTS	3.2	2.3	2.7	< 1.0	3.6
Total Sulphur	mg/kg	50	MCERTS	540	560	630	94	590
Total Organic Carbon (TOC)	%	0.1	MCERTS	3.5	1.2	4.0	0.5	4.3
Loss on Ignition @ 450°C	%	0.2	MCERTS	8.6	4.5	9.5	1.9	9.9

Total Phenols

Total Phenols (monohydric)	mg/kg	1	MCERTS	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0
----------------------------	-------	---	--------	-------	-------	-------	-------	-------

Speciated PAHs

Naphthalene	mg/kg	0.05	MCERTS	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05
Acenaphthylene	mg/kg	0.05	MCERTS	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05
Acenaphthene	mg/kg	0.05	MCERTS	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05
Fluorene	mg/kg	0.05	MCERTS	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05
Phenanthrene	mg/kg	0.05	MCERTS	1.2	< 0.05	0.50	< 0.05	1.3
Anthracene	mg/kg	0.05	MCERTS	0.23	< 0.05	< 0.05	< 0.05	0.22
Fluoranthene	mg/kg	0.05	MCERTS	2.5	< 0.05	0.95	< 0.05	2.5
Pyrene	mg/kg	0.05	MCERTS	2.0	< 0.05	0.75	< 0.05	2.0
Benzo(a)anthracene	mg/kg	0.05	MCERTS	1.2	< 0.05	0.57	< 0.05	1.5
Chrysene	mg/kg	0.05	MCERTS	1.4	< 0.05	0.58	< 0.05	1.4
Benzo(b)fluoranthene	mg/kg	0.05	MCERTS	1.8	< 0.05	0.87	< 0.05	2.0
Benzo(k)fluoranthene	mg/kg	0.05	MCERTS	0.41	< 0.05	0.28	< 0.05	0.63
Benzo(a)pyrene	mg/kg	0.05	MCERTS	1.0	< 0.05	0.49	< 0.05	1.2
Indeno(1,2,3-cd)pyrene	mg/kg	0.05	MCERTS	0.56	< 0.05	0.28	< 0.05	0.66
Dibenz(a,h)anthracene	mg/kg	0.05	MCERTS	0.23	< 0.05	< 0.05	< 0.05	0.16
Benzo(ghi)perylene	mg/kg	0.05	MCERTS	0.64	< 0.05	0.34	< 0.05	0.78

Total PAH

Speciated Total EPA-16 PAHs	mg/kg	0.8	MCERTS	13.2	< 0.80	5.61	< 0.80	14.3
-----------------------------	-------	-----	--------	------	--------	------	--------	------

Heavy Metals / Metalloids

Arsenic (aqua regia extractable)	mg/kg	1	MCERTS	14	11	15	5.6	14
Beryllium (aqua regia extractable)	mg/kg	0.06	MCERTS	0.84	1.1	0.69	0.70	0.72
Boron (water soluble)	mg/kg	0.2	MCERTS	1.1	1.3	1.0	0.3	0.7
Cadmium (aqua regia extractable)	mg/kg	0.2	MCERTS	0.5	< 0.2	< 0.2	< 0.2	< 0.2
Chromium (hexavalent)	mg/kg	4	MCERTS	< 4.0	< 4.0	< 4.0	< 4.0	< 4.0
Chromium (aqua regia extractable)	mg/kg	1	MCERTS	22	27	18	19	17
Copper (aqua regia extractable)	mg/kg	1	MCERTS	31	13	24	5.4	25
Lead (aqua regia extractable)	mg/kg	1	MCERTS	66	29	57	15	61
Mercury (aqua regia extractable)	mg/kg	0.3	MCERTS	< 0.3	< 0.3	< 0.3	< 0.3	< 0.3
Nickel (aqua regia extractable)	mg/kg	1	MCERTS	21	24	19	27	18
Selenium (aqua regia extractable)	mg/kg	1	MCERTS	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0
Vanadium (aqua regia extractable)	mg/kg	1	MCERTS	30	32	29	21	26
Zinc (aqua regia extractable)	mg/kg	1	MCERTS	120	81	89	57	90

Iss No 20-85054-1 Riverside Merthyr 12421

This certificate should not be reproduced, except in full, without the express permission of the laboratory.
The results included within the report are representative of the samples submitted for analysis.



Analytical Report Number: 20-85054

Project / Site name: Riverside Merthyr

Lab Sample Number				1433047	1433048	1433049	1433050	1433051
Sample Reference				Plot 61 Topsoil	Plot 61 Subsoil	Plot 63 Topsoil	Plot 63 Subsoil	Plot 68 Topsoil
Sample Number				None Supplied	None Supplied	None Supplied	None Supplied	None Supplied
Depth (m)				0.10	0.40	0.10	0.40	0.10
Date Sampled				04/02/2020	04/02/2020	04/02/2020	04/02/2020	04/02/2020
Time Taken				None Supplied	None Supplied	None Supplied	None Supplied	None Supplied
Analytical Parameter (Soil Analysis)	Units	Limit of detection	Accreditation Status					

Petroleum Hydrocarbons

TPH-CWG - Aliphatic >EC5 - EC6	mg/kg	0.001	MCERTS	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001
TPH-CWG - Aliphatic >EC6 - EC8	mg/kg	0.001	MCERTS	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001
TPH-CWG - Aliphatic >EC8 - EC10	mg/kg	0.001	MCERTS	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001
TPH-CWG - Aliphatic >EC10 - EC12	mg/kg	1	MCERTS	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0
TPH-CWG - Aliphatic >EC12 - EC16	mg/kg	2	MCERTS	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0
TPH-CWG - Aliphatic >EC16 - EC21	mg/kg	8	MCERTS	< 8.0	< 8.0	< 8.0	< 8.0	< 8.0
TPH-CWG - Aliphatic >EC21 - EC35	mg/kg	8	MCERTS	< 8.0	< 8.0	< 8.0	< 8.0	< 8.0
TPH-CWG - Aliphatic >EC16 - EC35	mg/kg	10	MCERTS	< 10	< 10	< 10	< 10	< 10
TPH-CWG - Aliphatic > EC35 - EC44	mg/kg	8.4	NONE	< 8.4	< 8.4	< 8.4	< 8.4	< 8.4
TPH-CWG - Aliphatic (EC5 - EC35)	mg/kg	10	MCERTS	< 10	< 10	< 10	< 10	< 10
TPH-CWG - Aliphatic (EC5 - EC44)	mg/kg	10	NONE	< 10	< 10	< 10	< 10	< 10

TPH-CWG - Aromatic >EC5 - EC7	mg/kg	0.001	MCERTS	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001
TPH-CWG - Aromatic >EC7 - EC8	mg/kg	0.001	MCERTS	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001
TPH-CWG - Aromatic >EC8 - EC10	mg/kg	0.001	MCERTS	< 0.001	< 0.001	< 0.001	< 0.001	< 0.001
TPH-CWG - Aromatic >EC10 - EC12	mg/kg	1	MCERTS	< 1.0	< 1.0	< 1.0	< 1.0	< 1.0
TPH-CWG - Aromatic >EC12 - EC16	mg/kg	2	MCERTS	< 2.0	< 2.0	< 2.0	< 2.0	< 2.0
TPH-CWG - Aromatic >EC16 - EC21	mg/kg	10	MCERTS	< 10	< 10	< 10	< 10	11
TPH-CWG - Aromatic >EC21 - EC35	mg/kg	10	MCERTS	28	< 10	22	< 10	18
TPH-CWG - Aromatic >EC35 - EC40	mg/kg	10	NONE	< 10	< 10	< 10	< 10	< 10
TPH-CWG - Aromatic > EC35 - EC44	mg/kg	8.4	NONE	< 8.4	< 8.4	< 8.4	< 8.4	< 8.4
TPH-CWG - Aromatic (EC5 - EC35)	mg/kg	10	MCERTS	36	< 10	28	< 10	28
TPH-CWG - Aromatic (EC5 - EC44)	mg/kg	10	NONE	36	< 10	28	< 10	28

TPH Total C5 - C44	mg/kg	10	NONE	36	< 10	28	< 10	28
---------------------------	-------	----	------	----	------	----	------	----

Iss No 20-85054-1 Riverside Merthyr 12421

This certificate should not be reproduced, except in full, without the express permission of the laboratory.
The results included within the report are representative of the samples submitted for analysis.

Analytical Report Number: 20-85054

Project / Site name: Riverside Merthyr

Lab Sample Number				1433052				
Sample Reference				Plot 68 Subsoil				
Sample Number				None Supplied				
Depth (m)				0.40				
Date Sampled				04/02/2020				
Time Taken				None Supplied				
Analytical Parameter (Soil Analysis)	Units	Limit of detection	Accreditation Status					
Stone Content	%	0.1	NONE	< 0.1				
Moisture Content	%	N/A	NONE	21				
Total mass of sample received	kg	0.001	NONE	0.50				

Asbestos in Soil	Type	N/A	ISO 17025	Not-detected				
------------------	------	-----	-----------	--------------	--	--	--	--

General Inorganics

pH - Automated	pH Units	N/A	MCERTS	8.7				
Total Cyanide	mg/kg	1	MCERTS	< 1				
Total Sulphate as SO ₄	mg/kg	50	MCERTS	1000				
Water Soluble SO ₄ 16hr extraction (2:1 Leachate Equivalent)	g/l	0.00125	MCERTS	0.18				
Sulphide	mg/kg	1	MCERTS	3.8				
Total Sulphur	mg/kg	50	MCERTS	560				
Total Organic Carbon (TOC)	%	0.1	MCERTS	1.0				
Loss on Ignition @ 450°C	%	0.2	MCERTS	3.9				

Total Phenols

Total Phenols (monohydric)	mg/kg	1	MCERTS	< 1.0				
----------------------------	-------	---	--------	-------	--	--	--	--

Speciated PAHs

Naphthalene	mg/kg	0.05	MCERTS	< 0.05				
Acenaphthylene	mg/kg	0.05	MCERTS	< 0.05				
Acenaphthene	mg/kg	0.05	MCERTS	< 0.05				
Fluorene	mg/kg	0.05	MCERTS	< 0.05				
Phenanthrene	mg/kg	0.05	MCERTS	< 0.05				
Anthracene	mg/kg	0.05	MCERTS	< 0.05				
Fluoranthene	mg/kg	0.05	MCERTS	0.34				
Pyrene	mg/kg	0.05	MCERTS	0.27				
Benzo(a)anthracene	mg/kg	0.05	MCERTS	0.15				
Chrysene	mg/kg	0.05	MCERTS	0.20				
Benzo(b)fluoranthene	mg/kg	0.05	MCERTS	< 0.05				
Benzo(k)fluoranthene	mg/kg	0.05	MCERTS	< 0.05				
Benzo(a)pyrene	mg/kg	0.05	MCERTS	< 0.05				
Indeno(1,2,3-cd)pyrene	mg/kg	0.05	MCERTS	< 0.05				
Dibenz(a,h)anthracene	mg/kg	0.05	MCERTS	< 0.05				
Benzo(ghi)perylene	mg/kg	0.05	MCERTS	< 0.05				

Total PAH

Speciated Total EPA-16 PAHs	mg/kg	0.8	MCERTS	0.96				
-----------------------------	-------	-----	--------	------	--	--	--	--

Heavy Metals / Metalloids

Arsenic (aqua regia extractable)	mg/kg	1	MCERTS	11				
Beryllium (aqua regia extractable)	mg/kg	0.06	MCERTS	1.1				
Boron (water soluble)	mg/kg	0.2	MCERTS	0.6				
Cadmium (aqua regia extractable)	mg/kg	0.2	MCERTS	< 0.2				
Chromium (hexavalent)	mg/kg	4	MCERTS	< 4.0				
Chromium (aqua regia extractable)	mg/kg	1	MCERTS	28				
Copper (aqua regia extractable)	mg/kg	1	MCERTS	16				
Lead (aqua regia extractable)	mg/kg	1	MCERTS	36				
Mercury (aqua regia extractable)	mg/kg	0.3	MCERTS	< 0.3				
Nickel (aqua regia extractable)	mg/kg	1	MCERTS	26				
Selenium (aqua regia extractable)	mg/kg	1	MCERTS	< 1.0				
Vanadium (aqua regia extractable)	mg/kg	1	MCERTS	35				
Zinc (aqua regia extractable)	mg/kg	1	MCERTS	91				

Iss No 20-85054-1 Riverside Merthyr 12421

This certificate should not be reproduced, except in full, without the express permission of the laboratory.

The results included within the report are representative of the samples submitted for analysis.

Page 4 of 8



Analytical Report Number: 20-85054

Project / Site name: Riverside Merthyr

Lab Sample Number				1433052				
Sample Reference				Plot 68 Subsoil				
Sample Number				None Supplied				
Depth (m)				0.40				
Date Sampled				04/02/2020				
Time Taken				None Supplied				
Analytical Parameter (Soil Analysis)	Units	Limit of detection	Accreditation Status					

Petroleum Hydrocarbons

TPH-CWG - Aliphatic >EC5 - EC6	mg/kg	0.001	MCERTS	< 0.001				
TPH-CWG - Aliphatic >EC6 - EC8	mg/kg	0.001	MCERTS	< 0.001				
TPH-CWG - Aliphatic >EC8 - EC10	mg/kg	0.001	MCERTS	< 0.001				
TPH-CWG - Aliphatic >EC10 - EC12	mg/kg	1	MCERTS	< 1.0				
TPH-CWG - Aliphatic >EC12 - EC16	mg/kg	2	MCERTS	< 2.0				
TPH-CWG - Aliphatic >EC16 - EC21	mg/kg	8	MCERTS	< 8.0				
TPH-CWG - Aliphatic >EC21 - EC35	mg/kg	8	MCERTS	< 8.0				
TPH-CWG - Aliphatic >EC16 - EC35	mg/kg	10	MCERTS	< 10				
TPH-CWG - Aliphatic > EC35 - EC44	mg/kg	8.4	NONE	< 8.4				
TPH-CWG - Aliphatic (EC5 - EC35)	mg/kg	10	MCERTS	< 10				
TPH-CWG - Aliphatic (EC5 - EC44)	mg/kg	10	NONE	< 10				

TPH-CWG - Aromatic >EC5 - EC7	mg/kg	0.001	MCERTS	< 0.001				
TPH-CWG - Aromatic >EC7 - EC8	mg/kg	0.001	MCERTS	< 0.001				
TPH-CWG - Aromatic >EC8 - EC10	mg/kg	0.001	MCERTS	< 0.001				
TPH-CWG - Aromatic >EC10 - EC12	mg/kg	1	MCERTS	< 1.0				
TPH-CWG - Aromatic >EC12 - EC16	mg/kg	2	MCERTS	< 2.0				
TPH-CWG - Aromatic >EC16 - EC21	mg/kg	10	MCERTS	< 10				
TPH-CWG - Aromatic >EC21 - EC35	mg/kg	10	MCERTS	24				
TPH-CWG - Aromatic >EC35 - EC40	mg/kg	10	NONE	< 10				
TPH-CWG - Aromatic > EC35 - EC44	mg/kg	8.4	NONE	< 8.4				
TPH-CWG - Aromatic (EC5 - EC35)	mg/kg	10	MCERTS	34				
TPH-CWG - Aromatic (EC5 - EC44)	mg/kg	10	NONE	34				

TPH Total C5 - C44	mg/kg	10	NONE	34				
---------------------------	-------	----	------	----	--	--	--	--

Iss No 20-85054-1 Riverside Merthyr 12421

This certificate should not be reproduced, except in full, without the express permission of the laboratory.
The results included within the report are representative of the samples submitted for analysis.



Analytical Report Number : 20-85054

Project / Site name: Riverside Merthyr

* These descriptions are only intended to act as a cross check if sample identities are questioned. The major constituent of the sample is intended to act with respect to MCERTS validation. The laboratory is accredited for sand, clay and loam (MCERTS) soil types. Data for unaccredited types of solid should be interpreted with care.

Stone content of a sample is calculated as the % weight of the stones not passing a 10 mm sieve. Results are not corrected for stone content.

Lab Sample Number	Sample Reference	Sample Number	Depth (m)	Sample Description *
1433047	Plot 61 Topsoil	None Supplied	0.10	Brown loam and clay with gravel and vegetation.
1433048	Plot 61 Subsoil	None Supplied	0.40	Brown clay and sand.
1433049	Plot 63 Topsoil	None Supplied	0.10	Brown loam and clay with gravel and vegetation.
1433050	Plot 63 Subsoil	None Supplied	0.40	Brown clay and sand.
1433051	Plot 68 Topsoil	None Supplied	0.10	Brown loam and clay with gravel and vegetation.
1433052	Plot 68 Subsoil	None Supplied	0.40	Brown clay and sand with vegetation.

Analytical Report Number : 20-85054

Project / Site name: Riverside Merthyr

Water matrix abbreviations: Surface Water (SW) Potable Water (PW) Ground Water (GW) Process Water (PrW)

Analytical Test Name	Analytical Method Description	Analytical Method Reference	Method number	Wet / Dry Analysis	Accreditation Status
Asbestos identification in soil	Asbestos Identification with the use of polarised light microscopy in conjunction with disperion staining techniques.	In house method based on HSG 248	A001-PL	D	ISO 17025
Boron, water soluble, in soil	Determination of water soluble boron in soil by hot water extract followed by ICP-OES.	In-house method based on Second Site Properties version 3	L038-PL	D	MCERTS
Hexavalent chromium in soil	Determination of hexavalent chromium in soil by extraction in water then by acidification, addition of 1,5 diphenylcarbazine followed by colorimetry.	In-house method	L080-PL	W	MCERTS
Loss on ignition of soil @ 450oC	Determination of loss on ignition in soil by gravimetrically with the sample being ignited in a muffle furnace.	In house method.	L047-PL	D	MCERTS
Metals in soil by ICP-OES	Determination of metals in soil by aqua-regia digestion followed by ICP-OES.	In-house method based on MEWAM 2006 Methods for the Determination of Metals in Soil.	L038-PL	D	MCERTS
Moisture Content	Moisture content, determined gravimetrically. (30 oC)	In house method.	L019-UK/PL	W	NONE
Monohydric phenols in soil	Determination of phenols in soil by extraction with sodium hydroxide followed by distillation followed by colorimetry.	In-house method based on Examination of Water and Wastewater 20th Edition: Clesceri, Greenberg & Eaton (skalar)	L080-PL	W	MCERTS
pH in soil (automated)	Determination of pH in soil by addition of water followed by automated electrometric measurement.	In house method.	L099-PL	D	MCERTS
Speciated EPA-16 PAHs in soil	Determination of PAH compounds in soil by extraction in dichloromethane and hexane followed by GC-MS with the use of surrogate and internal standards.	In-house method based on USEPA 8270	L064-PL	D	MCERTS
Stones content of soil	Standard preparation for all samples unless otherwise detailed. Gravimetric determination of stone > 10 mm as % dry weight.	In-house method based on British Standard Methods and MCERTS requirements.	L019-UK/PL	D	NONE
Sulphate, water soluble, in soil (16hr extraction)	Determination of water soluble sulphate by ICP-OES. Results reported directly (leachate equivalent) and corrected for extraction ratio (soil equivalent).	In house method.	L038-PL	D	MCERTS
Sulphide in soil	Determination of sulphide in soil by acidification and heating to liberate hydrogen sulphide, trapped in an alkaline solution then assayed by ion selective electrode.	In-house method	L010-PL	D	MCERTS
Total cyanide in soil	Determination of total cyanide by distillation followed by colorimetry.	In-house method based on Examination of Water and Wastewater 20th Edition: Clesceri, Greenberg & Eaton (Skalar)	L080-PL	W	MCERTS
Total organic carbon (Automated) in soil	Determination of organic matter in soil by oxidising with potassium dichromate followed by titration with iron (II) sulphate.	In house method.	L009-PL	D	MCERTS
Total sulphate (as SO4 in soil)	Determination of total sulphate in soil by extraction with 10% HCl followed by ICP-OES.	In house method.	L038-PL	D	MCERTS
Total Sulphur in soil	Determination of total sulphur in soil by extraction with aqua-regia, potassium bromide/bromate followed by ICP-OES.	In house method.	L038-PL	D	MCERTS
TPH in (Soil)	Determination of TPH bands by HS-GC-MS/GC-FID	In-house method, TPH with carbon banding and silica gel split/cleanup.	L076-PL	D	NONE

Iss No 20-85054-1 Riverside Merthyr 12421

This certificate should not be reproduced, except in full, without the express permission of the laboratory.

The results included within the report are representative of the samples submitted for analysis.

Page 7 of 8



Analytical Report Number : 20-85054

Project / Site name: Riverside Merthyr

Water matrix abbreviations: Surface Water (SW) Potable Water (PW) Ground Water (GW) Process Water (PrW)

Analytical Test Name	Analytical Method Description	Analytical Method Reference	Method number	Wet / Dry Analysis	Accreditation Status
TPHCWG (Soil)	Determination of hexane extractable hydrocarbons in soil by GC-MS/GC-FID.	In-house method with silica gel split/clean up.	L088/76-PL	W	MCERTS

For method numbers ending in 'UK' analysis have been carried out in our laboratory in the United Kingdom.

For method numbers ending in 'PL' analysis have been carried out in our laboratory in Poland.

Soil analytical results are expressed on a dry weight basis. Where analysis is carried out on as-received the results obtained are multiplied by a moisture correction factor that is determined gravimetrically using the moisture content which is carried out at a maximum of 30oC.

APPENDIX C

SUMMMARY OF CHEMICAL TESTING RESULTS

SUMMARY OF LABORATORY SOIL TEST RESULTS

METALS AND SEMI-METALS

Job No.: 12421
 Site: Riverside, Merthyr Vale
 Soil Type: Topsoil/subsoil
 Soil Organic Matter: 1%

No.	Location	Depth (m)	Arsenic (mg/kg)	Boron (mg/kg)	Beryllium (mg/kg)	Cadmium (mg/kg)	Chromium (mg/kg)	Chromium (VI) (mg/kg)	Copper (mg/kg)	Lead (mg/kg)	Mercury (Elemental) (mg/kg)	Nickel (mg/kg)	Selenium (mg/kg)	Vanadium (mg/kg)	Zinc (mg/kg)
27	Plot 61 Topsoil	0.10	14	1.1	0.84	0.5	22	< 4.0	31	66	< 0.3	21	< 1.0	30	120
28	Plot 61 Subsoil	0.40	11	1.3	1.1	< 0.2	27	< 4.0	13	29	< 0.3	24	< 1.0	32	81
29	Plot 63 Topsoil	0.10	15	1.0	0.69	< 0.2	18	< 4.0	24	57	< 0.3	19	< 1.0	29	89
30	Plot 63 Subsoil	0.40	5.6	0.3	0.70	< 0.2	19	< 4.0	5.4	15	< 0.3	27	< 1.0	21	57
31	Plot 68 Topsoil	0.10	14	0.7	0.72	< 0.2	17	< 4.0	25	61	< 0.3	18	< 1.0	26	90
32	Plot 68 Subsoil	0.40	11	0.6	1.1	< 0.2	28	< 4.0	16	36	< 0.3	26	< 1.0	35	91
Screening Criteria Value			37.0	290.0	1.7	22.0	-	21.0	2400.0	200.0	1.2	130.0	250.0	410.0	3700.0
Source of Screening Criteria Value			C4SL	S4UL	S4UL	C4SL	-	C4SL	S4UL	C4SL	S4UL	S4UL	S4UL	S4UL	S4UL

SUMMARY OF LABORATORY SOIL TEST RESULTS

INORGANIC CHEMICALS & OTHERS

Job No.: 12421
 Site: Riverside, Merthyr Vale
 Soil Type: Topsoil/subsoil
 Soil Organic Matter: 1%

No.	Location	Depth (m)	Cyanide (mg/kg)	Loss on ignition, dried solids (%)	Moisture content at 30 C (%)	Phenol (mg/kg)	pH (pH units)	Water Soluble Sulphate (g/l)	Sulphate Total as SO4 (mg/kg)	Sulphide (mg/kg)	Total Sulphur (mg/kg)	TOC by Ignition in O2 (%)	Equivalent SOM (%)	Asbestos in Soil	Asbestos Quantification (%)
27	Plot 61 Topsoil	0.10	< 1	8.6	23	< 1.0	7.4	0.031	650	3.2	540	3.5	6.02	Not-detected	#N/A
28	Plot 61 Subsoil	0.40	< 1	4.5	23	< 1.0	8.7	0.19	1100	2.3	560	1.2	2.06	Not-detected	#N/A
29	Plot 63 Topsoil	0.10	< 1	9.5	30	< 1.0	7.3	0.041	870	2.7	630	4.0	6.88	Not-detected	#N/A
30	Plot 63 Subsoil	0.40	< 1	1.9	10	< 1.0	7.6	0.015	180	< 1.0	94	0.5	0.86	Not-detected	#N/A
31	Plot 68 Topsoil	0.10	< 1	9.9	29	< 1.0	7.4	0.042	920	3.6	590	4.3	7.40	Not-detected	#N/A
32	Plot 68 Subsoil	0.40	< 1	3.9	21	< 1.0	8.7	0.18	1000	3.8	560	1.0	1.72	Not-detected	#N/A
Screening Criteria Value			34.0	-	-	280.0	-	-	-	-	-	-	-	-	0.001
Source of Screening Criteria Value			ATRISK	-	-	S4UL	-	-	-	-	-	-	-	-	IOM

SUMMARY OF LABORATORY SOIL TEST RESULTS

POLYAROMATIC HYDROCARBONS (PAH)

Job No.: 12421
 Site: Riverside, Merthyr Vale
 Soil Type: Topsoil/subsoil
 Soil Organic Matter: 1%

No.	Location	Depth (m)	Acenaphthene (mg/kg)	Acenaphthylene (mg/kg)	Anthracene (mg/kg)	Benzo(a)anthracene (mg/kg)	Benzo(a)pyrene (mg/kg)	Benzo(b)fluoranthene (mg/kg)	Benzo(ghi)perylene (mg/kg)	Benzo(k)fluoranthene (mg/kg)	Chrysene (mg/kg)	Dibenzo(ah)anthracene (mg/kg)	Fluoranthene (mg/kg)	Fluorene (mg/kg)	Indeno(123cd)pyrene (mg/kg)	Naphthalene (mg/kg)	Phenanthrene (mg/kg)	Pyrene (mg/kg)
27	Plot 61 Topsoil	0.10	< 0.05	< 0.05	0.23	1.2	1.0	1.8	0.64	0.41	1.4	0.23	2.5	< 0.05	0.56	< 0.05	1.2	2.0
28	Plot 61 Subsoil	0.40	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05
29	Plot 63 Topsoil	0.10	< 0.05	< 0.05	< 0.05	0.57	0.49	0.87	0.34	0.28	0.58	< 0.05	0.95	< 0.05	0.28	< 0.05	0.50	0.75
30	Plot 63 Subsoil	0.40	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05	< 0.05
31	Plot 68 Topsoil	0.10	< 0.05	< 0.05	0.22	1.5	1.2	2.0	0.78	0.63	1.4	0.16	2.5	< 0.05	0.66	< 0.05	1.3	2.0
32	Plot 68 Subsoil	0.40	< 0.05	< 0.05	< 0.05	0.15	< 0.05	< 0.05	< 0.05	< 0.05	0.20	< 0.05	0.34	< 0.05	< 0.05	< 0.05	< 0.05	0.27
Screening Criteria Value			210.0	170.0	2400.0	7.2	5.0	2.6	320.0	77.0	15.0	0.2	280.0	170.0	27.0	2.3	95.0	620.0
Source of Screening Criteria Value			S4UL	S4UL	S4UL	S4UL	C4SL	S4UL	S4UL	S4UL	S4UL	S4UL	S4UL	S4UL	S4UL	S4UL	S4UL	S4UL

SUMMARY OF LABORATORY SOIL TEST RESULTS

PETROLEUM HYDROCARBONS

Job No.: 12421
 Site: Riverside, Merthyr Vale
 Soil Type: Topsoil/subsoil
 Soil Organic Matter: 1%

No.	Location	Depth (m)	Aliphatic C5-C6 (mg/kg)	Aliphatic C6-C8 (mg/kg)	Aliphatic C8-C10 (mg/kg)	Aliphatic C10- C12 EPH (mg/kg)	Aliphatic C12- C16 EPH (mg/kg)	Aliphatic C16-C35 EPH (mg/kg)	Aliphatic C35- C44 EPH (mg/kg)	Aromatic C5-C7 (mg/kg)	Aromatic C7-C8 (mg/kg)	Aromatic C8-C10 (mg/kg)	Aromatic C10- C12 EPH (mg/kg)	Aromatic C12- C16 EPH (mg/kg)	Aromatic C16- C21 EPH (mg/kg)	Aromatic C21- C35 EPH (mg/kg)	Aromatic C35- C40 EPH (mg/kg)
27	Plot 61 Topsoil	0.10	< 0.001	< 0.001	< 0.001	< 1.0	< 2.0	< 10	< 8.4	< 0.001	< 0.001	< 0.001	< 1.0	< 2.0	< 10	< 10	< 8.4
28	Plot 61 Subsoil	0.40	< 0.001	< 0.001	< 0.001	< 1.0	< 2.0	< 10	< 8.4	< 0.001	< 0.001	< 0.001	< 1.0	< 2.0	< 10	< 10	< 8.4
29	Plot 63 Topsoil	0.10	< 0.001	< 0.001	< 0.001	< 1.0	< 2.0	< 10	< 8.4	< 0.001	< 0.001	< 0.001	< 1.0	< 2.0	< 10	< 10	< 8.4
30	Plot 63 Subsoil	0.40	< 0.001	< 0.001	< 0.001	< 1.0	< 2.0	< 10	< 8.4	< 0.001	< 0.001	< 0.001	< 1.0	< 2.0	< 10	< 10	< 8.4
31	Plot 68 Topsoil	0.10	< 0.001	< 0.001	< 0.001	< 1.0	< 2.0	< 10	< 8.4	< 0.001	< 0.001	< 0.001	< 1.0	< 2.0	11	18	< 8.4
32	Plot 68 Subsoil	0.40	< 0.001	< 0.001	< 0.001	< 1.0	< 2.0	< 10	< 8.4	< 0.001	< 0.001	< 0.001	< 1.0	< 2.0	< 10	24	< 8.4
Screening Criteria Value			42.0	100.0	27.0	130.0	1100.0	65000.0	65000.0	0.9	130.0	34.0	74.0	140.0	260.0	1100.0	1100.0
Source of Screening Criteria Value			S4UL	S4UL	S4UL	S4UL	S4UL	S4UL	S4UL	C4SL	S4UL	S4UL	S4UL	S4UL	S4UL	S4UL	S4UL