

Dimensions are not to be scaled from this drawing



Kingfisher Lighting

Part of the Luceco PLC group of companies



Sheltered Housing



A1

Calculation Summary

Project: Project_1

Label

Rugby Field

Rugby Try Zone

Rugby Try Zone 2

CalcType

illuminance

illuminance

illuminance

Units

Lux

Lux

Lux

Avg

377.94

509

266

Max

509

266

235

Min

0.70

0.52

0.80

Min/Avg

0.70

0.52

0.65

0.62

Luminaire Schedule

Symbol

Qty

Label

Arrangement

Description

1 x 1350W Amnis Flood with NST Optic Mounted @ 18m

Merthyr RFC



For our LED lighting designs a 0.9mf has been used. If this differs from the maintenance period for this project then you must advise us accordingly

A lighting applications design service is provided by us in good faith and without charge, relating to Kingfisher products only. As such, whilst every endeavor is made for accuracy from information provided by yourselves, the final responsibility for the suitability of the design lies with the client. The company cannot, therefore, accept any liability or consequential loss incurred.

Scale

1:400 at A1

Project Number

E30763

Date

29 July 2020

Drawing No.

30763/PJ/C

Lighting Designer: Paul James