

INTERNAL MEMORANDUM

To : Huw Roberts
From : Landscape Architect
Ask for : Tom Bramley
Ext. : 6276

Date : 11th February 2020

SUBJECT: P/20/0025- Engineering works including provisio of drainage channel/ swale and culvert/outflow, raising the level of the land, and creation of site access road at Former Ardagh Site Dragon Parc Abercanaid

With regards to the above application f please find the following observations.

The following areas of concern are in need of address:

- An application for a licence to use herbicide adjacent to watercourses from Natural Resources Wales.
- A specification is required for the membrane to be used for the temporary storage of Japanese Knotweed.
- Appropriate licenses with be required for the movement of rhizomes to a licensed landfill facility.
- Methods of protection to avoid the distribution of Japanese Knotweed fragments or rhizomes within the water course system.

Kind regards

Tom Bramley – Landscape Architect