

From: Davies, Liam (Highways) <Liam.Davies@merthyr.gov.uk>

Sent: Monday, August 19, 2024 11:50 AM

To: Glover, Kate <Kate.Glover@merthyr.gov.uk>


Subject: RE: 24/0186 [NOT PROTECTIVELY MARKED]

Classification: NOT PROTECTIVELY MARKED

Hi Kate

Please see comments below regarding the application **24/0186**

- The applicant should be made aware that the proposed scheme will require a highway licence and should therefore contact the council's Highway Maintenance Department regarding the approval of a section 184 license in relation to any the proposed vehicular crossovers. This this must be obtained separate to this planning permission.
- Disabled bay is acceptable in terms of size
- In regards to the dropped kerbing. I have sketched something below that I would like to see.
 - Blue should be full height HB2 kerbing across the length of the access path
 - Red hatched is existing dropped kerbing
 - Red (NOT hatched) is proposed dropped kerb and transition kerbing across the length of the new bay



Thanks

Liam

Liam Davies

Peiriannydd Rheoli Traffig Cynorthwyol / Assistant Traffic Management Engineer

Cyngor Bwrdeistref Sirol Merthyr Tudful / Merthyr Tydfil County Borough Council

Uned 5, Parc Business Triogl, Pentrebach, Merthyr Tudful, CF48 4TQ

Unit 5, Triangle Business Park, Pentrebach, Merthyr Tydfil, CF48 4TQ

- ☐ Ffôn/Phone: 07542226455
- ☐ E-Bost/Email: liam.davies@merthyr.gov.uk