

Merthyr Tydfil County Council
The Planning Division
Unit 5 Triangle Business Park
PENTREBACH
Merthyr Tydfil, Mid Glamorgan
CF48 4TQ

Date: 24/09/2025
Our Ref: PLA0090173
Your Ref: P/25/0247

Dear Sir/Madam,

Grid Ref: SO052050 305288 205023

Site: JLC Groundwork Contractors Ltd, Willow Works, Merthyr Tydfil

Development: New storage unit with office

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

Water Supply

We anticipate this development will require the installation of a new single water connection to serve the new premise. Capacity is available in the water supply system to accommodate the development. The applicant will need to apply to Dwr Cymru Welsh Water for a connection to the potable water supply system under Section 45 of the Water Industry Act 1991. The applicant attention is drawn to our new water connection application guidance notes available on our website.

Asset Protection

This site is crossed by a public watermain with the approximate position being marked on the attached statutory public watermain record. In accordance with the Water Industry Act 1991, Dwr Cymru Welsh Water requires access to its apparatus at all times in order to carry out maintenance and repairs. Having regard to the submitted Proposed Plans, it appears the proposed development would be situated directly above the public asset, which has a protection zone measured 4.45 metres either side of the centreline. Please note, the distance specified for this protection zone is indicative and based on industry standard guidelines. However, the depth of the asset will need to be verified on site which may infer a greater protection zone. For completeness, we recommend the developer refer to their title deeds to confirm if there are any covenants or restrictions associated with the asset crossing the proposed development site.

In this instance, it appears there is sufficient space and scope to re-position the development outside the protection zone of the asset. Therefore, it is strongly recommended that the proposal is amended to take into account the location of the asset crossing the site and we respectfully request we are re-consulted on receipt of this information. It is also recommended that the developer contact our Plan and Protect team (PlanandProtect@dwrcymru.com) to carry out a survey to verify the location of the asset and establish their relationship to the proposed development.

Accordingly, for the reasons outlined above, we offer a **Holding Objection** until such time as amended information has been submitted and request we are re-consulted on receipt of this information.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Bethan Davies
Development Planning Officer
Developer Services



Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in
Welsh and English

Dŵr Cymru Cyf, a limited company registered in
Wales no 2366777. Registered office: Pentwyn Road,
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn
Nelson, Treharris, Morgannwg Ganol CF46 6LY.