
From: Davies, Matthew (Planning)
Sent: 05 April 2022 15:10
To: Roberts, Huw
Subject: RE: Planning application P/21/0332 - Erection of 4, 15m high floodlights at YYG Rugby Pitch. [NOT PROTECTIVELY MARKED]

Classification: NOT PROTECTIVELY MARKED
Classification: NOT PROTECTIVELY MARKED

Dear Huw

Yes, the proposal is acceptable as the new lighting scheme represents an improvement in terms of lighting, which is likely to reduce negative impacts on local biodiversity.

Best wishes

Matt

From: Roberts, Huw <Huw.Roberts@merthyr.gov.uk>
Sent: 05 April 2022 15:00
To: Davies, Matthew (Planning) <Matthew.Davies3@merthyr.gov.uk>
Subject: Planning application P/21/0332 - Erection of 4, 15m high floodlights at YYG Rugby Pitch.

Hi Matt, further to our conversation, given the fact that:

- the lights would be 3000k;
- the spillage would be similar to that of the previous lighting and;
- the lights would only be utilised 6.00 – 9.30 on Monday, Tuesday, Wednesday and Thursday and not at all on Fridays, Saturdays and Sundays (i.e. a betterment because there was no restricted use of previously lighting)

can you confirm that there would be an enhancement in terms of biodiversity and as such the proposal is acceptable?

Many thanks

Huw