

INTERNAL MEMORANDUM

Your Ref.: P/22/0203

Our Ref.: 22/0203

To: Town Planning Division – Development Control Section

FAO: Caroline Pulley

From: Engineering and Highways Division – Highway Development Control Section

Please ask for: Martyn Tanner

Date: 18/08/2022

OBSERVATIONS BY THE ENGINEERING AND HIGHWAYS DIVISION IN RESPECT OF DEVELOPMENT AFFECTING EXISTING OR PROPOSED PUBLICLY MAINTAINED HIGHWAY

PROPOSED DEVELOPMENT

Replacement bridge with handrails and associated engineering works and provision of culvert at Maestaf Street Bridge Pentrebach.

PLANNING HISTORY

None.

HIGHWAY ASSESSMENT

The proposal involves the demolition of the existing bridge on Maestaf Street, Pentrebach and construction of a pre-cast concrete box culvert in its place. The proposal includes provision of parapet fencing and high containment kerbs. The inclusion of high containment kerbs narrows the available footway width; however, the 1.295m width indicated on submitted drawing no. "003-GA-01 Rev 02" is above the 'restricted width at immovable object' width of 1.2m indicated within Active Travel Act Guidance and is only for a short length of 7.2m

The detailed design of the proposal is being undertaken in house by the Council's own Engineering and Traffic Section's Projects Team who will ensure its proper design and construction.

RECOMMENDATION

No highway objection is raised nor condition(s) suggested.

NOTES

None.