



EV Charging

- IP Rated Junction Box where space is adjacent
- 32mm Duct from IP Rated Junction box on house to ground box by parking bay

Smart chargers to be installed on all Kielder & Knebworth properties.

6mm armoured cable from consumer unit to IP rated junction box.

Individual ducts from each property to each ground box.

Ground box to be nominal 300mm x 300mm x 300mm deep with suitable cover for anticipated loadings.

Draw cord to be provided in all ducts and hockey stick to IP rated box.

Twynrodyn
Merthyr Tydfil

EV Charging Plan

Drawing No. EV-01 Drawing by: RJ

Scale: 1:500 @ A0 Checked by: Technical

Date: 10.08.2022 Status: Planning

Persimmon Homes
East Wales

Persimmon Homes
Llanfair Business Park
Llanfair
Rhonda Cymun Telf
0772 8191
Tel: 01443 223 653