



200 Lichfield Lane
Berry Hill
Mansfield
Nottinghamshire
NG18 4RG

Tel: 01623 637 119 (Planning Enquiries)

Email: planningconsultation@coal.gov.uk

Web: www.gov.uk/coalauthority



The Coal
Authority

For the Attention of: Mr Steven Isaac

[By Email: SIsaac@Tenneco.com]

11 January 2019

Dear Mr Isaac

PRE APPLICATION ENQUIRY: TCA-PPA-18-0049

Confirmation of whether a CMRA is required for an extension to a commercial building; Tenneco Walker Ltd, High Point, Merthyr Tydfil, Mid Glamorgan, CF48 2TA

I refer to your enquiry received on 7 January 2019 in respect of the above.

The Coal Authority is a non-departmental public body sponsored by the Department for Business, Energy & Industrial Strategy. As a statutory consultee, The Coal Authority has a duty to respond to planning applications and development plans in order to protect the public and the environment in mining areas.

The Coal Authority records indicate that the site is likely to have been subject to historic unrecorded underground coal mining at shallow depth and that a thick coal seam outcropped across the site.

The proposal you set out is for an extension, albeit of temporary construction, to the existing commercial building.

As you will be aware, The Coal Authority's general approach in cases where development is proposed within the Development High Risk Area is to recommend that the applicant obtains coal mining information for the application site and submits a Coal Mining Risk Assessment to support the planning application.

However, when considering the nature of this proposal we do not consider that it would be proportionate to require any formal planning application for this development to be supported by a Coal Mining Risk Assessment.

We would however wish for your attention to be drawn to the following Informative Note in the interests of public safety:

The proposed development lies within an area that has been defined by the Coal Authority as containing potential hazards arising from former coal mining activity. These hazards can include: mine entries (shafts and adits); shallow coal workings; geological features (fissures and break lines); mine gas and previous surface mining sites. Although such hazards are seldom readily visible, they can often be present and problems can occur in the future, particularly as a result of development taking place.

It is recommended that information outlining how the former mining activities affect the proposed development, along with any mitigation measures required (for example the need for gas protection measures within the foundations), be submitted alongside any subsequent application for Building Regulations approval (if relevant).

Any intrusive activities which disturb or enter any coal seams, coal mine workings or coal mine entries (shafts and adits) requires a Coal Authority Permit. Such activities could include site investigation boreholes, digging of foundations, piling activities, other ground works and any subsequent treatment of coal mine workings and coal mine entries for ground stability purposes. Failure to obtain a Coal Authority Permit for such activities is trespass, with the potential for court action.

Property specific summary information on past, current and future coal mining activity can be obtained from: www.groundstability.com or a similar service provider.

If any of the coal mining features are unexpectedly encountered during development, this should be reported immediately to the Coal Authority on 0345 762 6848. Further information is available on the Coal Authority website at: www.gov.uk/coalauthority

Please do not hesitate to contact me if you would like to discuss this matter further.

Yours sincerely

Chris MacArthur

Chris MacArthur B.Sc.(Hons), DipTP, MRTPI
Planning Liaison Manager

Disclaimer

The above consultation response is provided by The Coal Authority as a Statutory Consultee and is based upon the latest available data on the date of the response, and electronic consultation records held by The Coal Authority since 1 April 2013. The comments made

are also based upon only the information provided to The Coal Authority by the Local Planning Authority and/or has been published on the Council's website for consultation purposes in relation to this specific planning application. The views and conclusions contained in this response may be subject to review and amendment by The Coal Authority if additional or new data/information (such as a revised Coal Mining Risk Assessment) is provided by the Local Planning Authority or the Applicant for consultation purposes.