
From: Davies, Liam (Highways)
Sent: 11 April 2024 12:15
To: Glover, Kate
Subject: RE: Planning App Consultation for P/24/0075 [NOT PROTECTIVELY MARKED]

Classification: NOT PROTECTIVELY MARKED

Hi Kate,

I've taken another look at this and have 2 more queries to raise relating to this application.

-The construction of the garage would need to be in accordance with welsh standards (3mx6m) -In relation to the crossover (as mentioned below), the material should be consolidated (not stone or chipping)

Kind regards

HDC

-----Original Message-----

From: HDC
Sent: 09 April 2024 10:56
To: Glover, Kate <Kate.Glover@merthyr.gov.uk>
Subject: RE: Planning App Consultation for P/24/0075 [NOT PROTECTIVELY MARKED]

Classification: NOT PROTECTIVELY MARKED

Hi Kate,

I've been looking at the application P/24/0075.

Unfortunately I cannot make a formal comment on the application until I have received further details regarding the plans -There is a telegraph pole adjacent to the proposed garage and you can see the stay cable is blocking the access to the garage. I need further details on how this problem will be overcome.

-no details of what form of construction will be installed in front of the garage have been provided e.g. vehicle crossover

Once I received these details I will be able to provide my comments

Kind regards

HDC

-----Original Message-----

From: Planning DC <Planning.DC@merthyr.gov.uk>
Sent: 08 April 2024 12:03
To: HDC <HDC@merthyr.gov.uk>
Subject: Planning App Consultation for P/24/0075

see attached