

Ein cyf/Our ref: CAS-263440-M5K4
Eich cyf/Your ref: P/24/0206

Merthyr Tydfil County Borough Council
Unit 5 Triangle Business Park
Pentrebach
CF48 4TQ

Dyddiad/Date: 18 September 2024

Annwyl Syr/Madam/Dear Sir/Madam,

BWRIAD/PROPOSAL: Erect new shopfront; demolish part of rear kitchen extension and alter its flat roof to a sloping roof; erect three storey rear extension.

LLEOLIAD/LOCATION: 148 High Street, Merthyr Tydfil, CF47 8DP.

Thank you for consulting Cyfoeth Naturiol Cymru (CNC)/Natural Resources Wales (NRW) about the above, which we received on 28 August 2024.

We have no objection to the proposed development as submitted and provide the following advice.

Our Flood Risk Map confirms the application site lies within Zone C2 of the Development Advice Maps (DAM) as contained in Technical Advice Note (TAN) 15: Development and Flood Risk (2004). The Flood Map for Planning identifies the application site to be at risk of flooding and falls partially into Flood Zone 2 and 3 Rivers.

Given the scale of the proposed development (and in the absence of a flood consequences assessment) we consider the proposals could be acceptable, subject to the developer being made aware of the potential flood risks and advised to install flood-proofing measures as part of the development.

In areas at risk of flooding, we recommend that consideration be given to the incorporation of flood resistance/resilience measures into the design and construction of the development. These could include flood barriers on ground floor doors, windows and access points, implementation of suitable flood proofing measures to the internal fabric of the ground floor and locating electrical sockets/components at a higher level above possible flood levels.

We refer the applicant to our [website](#) for further advice and guidance is available. Additional guidance including the leaflet "Prepare your Property for flooding" can be found [here](#).

The developer can also access advice and information on protection from flooding from the ODPM publication 'Preparing for Floods: Interim Guidance for Improving the Flood Resistance of Domestic and Small Business Properties', can be found [here](#).

Other Matters

Our comments above only relate specifically to matters included on our checklist, *Development Planning Advisory Service: Consultation Topics* (September 2018), which is published on our [website](#). We have not considered potential effects on other matters and do not rule out the potential for the proposed development to affect other interests.

We advise the applicant that, in addition to planning permission, it is their responsibility to ensure they secure all other permits/consents/licences relevant to their development. Please refer to our [website](#) for further details.

If you have any queries on the above, please do not hesitate to contact us.

Yn gywir / Yours faithfully,

Rhian Isaac

Cynghorydd - Cynllunio Datblygu/Advisor - Development Planning
Cyfoeth Naturiol Cymru/Natural Resources Wales

E-bost/E-mail: southeastplanning@cyfoethnaturiolcymru.gov.uk

Croesewir gohebiaeth yn Gymraeg a byddwn yn ymateb yn Gymraeg, heb i hynny arwain at oedi./Correspondence in Welsh is welcomed, and we will respond in Welsh without it leading to a delay.