

## **Pulley, Caroline**

---

**From:** Marley, Lucy  
**Sent:** 23 September 2020 15:42  
**To:** Pulley, Caroline  
**Subject:** P/20/0204 - comments from Environmental Protection [NOT PROTECTIVELY MARKED]

**Classification: NOT PROTECTIVELY MARKED**

Hi Caroline,

With reference to the above planning application, please note the following comments from this department:

Construction should be limited to the following hours in line with Sec.60 of the Control of Pollution Act 1974 in order to protect nearby residential development from noise nuisance:

Mon – Fri – 8am – 6pm

Sat – 8am – 1pm

Sundays and bank holidays – No noisy works on site.

If works are required to be carried out, outside of these hours, the contractor must contact the Environmental Protection department of the Council to discuss any proposed deviation before proceeding, unless it is of an emergency nature. The latter should be reported to the Council as soon as practicably possible afterwards.

Noisy plant or equipment should be placed as far from nearby residential development where possible. Use of barriers to reduce noise reaching noise sensitive buildings should be made where practicable.

No burning shall be carried out on site and dust suppression measures must be employed where necessary.

No effluent or unauthorised deposit shall be made into the existing drainage system so as to cause contamination of waterways or groundwater.

All waste materials must be removed from site and disposed of by a registered waste carrier at a tip licenced for its reception.

Kind regards

**Lucy Marley**

**Swyddog Iechyd yr Amgylchedd / Environmental Health Officer**

**Diogelu'r Amgylchedd a Thai, Adran Amgylchedd Iechyd / Environmental Protection and Housing, Environmental Health Department**

**Cyngor Bwrdeistref Sirol Merthyr Tudful / Merthyr Tydfil County Borough Council**

**Canolfan Ddinesig / Civic Centre**

**Stryd Y Castell / Castle Street**

**Merthyr Tudful / Merthyr Tydfil**

**CF47 8AN**

**Ffon / Tel: 01685 725395**

