

7.0. CONCLUSIONS.

1. There is no risk to site stability arising from either existing geological features or past mining activity.
2. The ground conditions are suitable for traditional mass concrete strip foundations adopting a maximum safe ground bearing pressure of 150KN/M2.
3. Subsoils are granular in nature and suitable for soakaway type of stormwater disposal.



G.A. SPACEY C.ENG. M.I. STRUCT E.

MAY 2008