

[REDACTED]


From: [REDACTED]
Sent: 05 June 2025 09:04
To: 'Davies, Gareth'
Cc: 'Williams, Christine'; 'Glover, Kate'; 'Cross, David'
Subject: FW: Retaining wall - Ysgol Santes Tydfil

Good Morning Gareth,

Hope you are well?

Please see email below from Andy Robbins (Structural Engineer) regarding the fencing on top of the walls / point load query raised.

Kind Regards,



RYAN WILLIAMS
MANAGING DIRECTOR

Tel: [REDACTED]
Email: [REDACTED]
www.priority.org.uk



Cardiff House, Priority Business Park, Vale of Glamorgan, CF63 2AW

From: Andrew Robbins [REDACTED]
Sent: 05 June 2025 07:54
To: [REDACTED]
Subject: Re: Retaining wall - Ysgol Santes Tydfil

Morning Ryan,

Thanks for your e-mail.

As discussed, the intention is to reinstate a lightweight railing, 1100mm high, to match existing.

Considering the retained height of the wall structure and the mass of the structure itself, we can confirm the self weight of a 1100mm high metal railing will be negligible. Weight of metal railings is typically 9kg per metre run which is only 0.09kN/m run.

Therefore, we are satisfied the designed retaining structure is more than adequate to support such

a minimal load.

I trust the above satisfies any queries raised. However, should any additional information be requested, please feel free to get back in touch.

Best Regards

Andrew

Andrew Robbins BEng(Hons), CEng, MStructE, MICE
Director

FAR Structures Ltd
Consulting Structural Engineers

t: [REDACTED]

On 03/06/2025 19:00, [REDACTED] wrote:


Hi Mate,

Apologies for the delay but it has been one of those days and now I am getting in.

Please see email below from local authority regarding point loads and fencing, etc.

As discussed, we are only proposing to reinstate and put new fencing back at the same height which will form a 1100mm or higher protection barrier to avoid anyone falling off the wall.

Kind Regards



RYAN WILLIAMS
MANAGING DIRECTOR

Tel: [REDACTED]

Email: [REDACTED]

www.priority.org.uk



Cardiff House, Priority Business Park, Vale of Glamorgan, CF63 2AW

From: Davies, Gareth [REDACTED]

Sent: 03 June 2025 11:52

To: [REDACTED]

Cc: Williams, Christine [REDACTED] >; Cross, David

[REDACTED] >; Glover, Kate [REDACTED] >

Subject: retaining wall - Ysgol Sates Tydfil

Hi

Haran has looked at the submitted details and has raised the following query

“are they going to have hand rail put on the top of the wall?, if its they have to apply point load on the top of the wall. In this case there is no point load.”

Please could you address the question so as we progress the discharge of the condition.

Kind regards

Gareth

Gareth Davies

Prif Swyddog Cynllunio / Principal Planning Officer

Ffôn / Tel:

E-bost / Email

Cyngor Bwrdeistref Sirol Merthyr Tudful / Merthyr Tydfil County Borough Council
Uned 5, Parc Fusness Triongl / Unit 5, Triangle Business Park
Pentrebach, Merthyr Tudful / Pentrebach, Merthyr Tydfil
CF48 4TQ

Croesawn ohebu yn Gymraeg a fydd hyn ddim yn arwain at oedi.

Mae'r e-bost hwn ac unrhyw ffeiliau a drosglwyddir gydag ef yn gyfrinachol ac wedi'u bwriadu ar gyfer pwy bynnag y cyfeirir ef ato neu atynt. Mae cynnwys yr e-bost hwn cynrychioli barn y sawl a enwir uchod, felly nid ydyw'n dilyn ei fod yn cynrychioli barn Cyngor Bwrdeistref Sirol Merthyr Tudful.

Darllenwch ein [hysbysadau preifatrwydd](#) i ddarganfod mwy am sut rydym yn defnyddio eich gwybodaeth bersonol.

Cyngor Bwrdeistref Sirol Merthyr Tudful

Canolfan Dinesig

Stryd Y Castell

Merthyr Tudful

CF47 8AN

Teleffon: 01685 725000

We welcome correspondence in Welsh and this will not lead to a delay.

This e-mail and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. The contents of this e-mail represent the views of the individual(s) named above and do not necessarily represent the views of Merthyr Tydfil County Borough Council.

Please read our [privacy notices](#) to find out more about how we use your personal information.

Merthyr Tydfil County Borough Council


Civic Centre

Castle Street

Merthyr Tydfil

CF47 8AN

Telephone: 01685 725000



<http://www.merthyr.gov.uk>

Croesawn ohebu yn Gymraeg a fydd hyn ddim yn arwain at oedi.

Mae'r e-bost hwn ac unrhyw ffeiliau a drosglwyddir gydag ef yn gyfrinachol ac wedi'u bwriadu ar gyfer pwy bynnag y cyfeirir ef ato neu atynt. Mae cynnwys yr e-bost hwn cynrychioli barn y sawl a enwir uchod, felly nid ydyw'n dilyn ei fod yn cynrychioli barn Cyngor Bwrdeistref Sirol Merthyr Tudful.

Darllenwch ein [hysbysiadau preifatrwydd](#) i ddarganfod mwy am sut rydym yn defnyddio eich gwybodaeth bersonol.

Cyngor Bwrdeistref Sirol Merthyr Tudful

Canolfan Dinesig
Stryd Y Castell
Merthyr Tudful
CF47 8AN

Teleffon: 01685 725000

We welcome correspondence in Welsh and this will not lead to a delay.


This e-mail and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. The contents of this e-mail represent the views of the individual(s) named above and do not necessarily represent the views of Merthyr Tydfil County Borough Council.

Please read our [privacy notices](#) to find out more about how we use your personal information.

Merthyr Tydfil County Borough Council

Civic Centre
Castle Street
Merthyr Tydfil
CF47 8AN

Telephone: 01685 725000



<http://www.merthyr.gov.uk>



Virus-free www.avg.com