

Vehicle Charging Point at Graig Terrace

- I agree with the amended description for this application.
- The connection to the post will be via an overhead cable connected to the clients side of the meter at his property and to a Vehicle charging point on a pedestal at the side of the post . Annotated drawing attached.
- The client has discussed this with Western Power. They will install the post and cable from his property to the charger.
- As the post is private and not used by the public it is being sited on private land, also there is no pavement on the side of the highway where the siting of the post is proposed so it needs to be sited on private land.
- Maintenance will be carried out by the Western Power.
- The recommended height of posts in a street is minimum of 5m. The post height will be in keeping with current post in the street.
- The post will be used to provide electricity to a vehicle charging point only. Detail of charging point shown on drawings.