

Merthyr Tydfil County  
The Planning Division  
Unit 5 Triangle Business Park  
PENTREBACH  
Merthyr Tydfil, Mid Glamorgan  
CF48 4TQ

**Date: 26/11/2025**  
**Our Ref: PLA0091529**  
**Your Ref: P/25/0298**

Dear Sir/Madam

**Grid Ref: SO055059 305599 205961**  
**Site: Builders Yard, Elwyn Drive, Merthyr Tydfil,**  
**Development: Convert builders yard office to 2no. flats at Former Builders Yard Elwyn Drive**

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

### **SURFACE WATER DRAINAGE**

We have reviewed the information submitted as part of the application and note that the intention is for surface water to be disposed of via sustainable means (soakaway) as demonstrated on submitted drawing 'Proposed Site Plan'. We recognise that the assessment of this method of disposal is the responsibility of the Lead Local Flood Authority / SAB. Notwithstanding the above, we refer to Planning Policy Wales which acknowledges that legislation prohibits the discharge of surface water to foul sewers. Furthermore, it highlights that any surface water from new developments should not be discharged to combined systems because of the risk of pollution when combined systems overflow (Para 6.6.3). Therefore, no amount of surface water will be permitted to communicate directly or indirectly with the public combined sewerage system.

### **SEWERAGE - FOUL WATER DRAINAGE**

In regard to the disposal of foul water we can provide the following comments.

The site lies within the catchment of Cilfynydd WwTW, and we can confirm hydraulic capacity exists within the public sewerage network in order to receive the domestic foul only flows from the proposed development site and this site only. This matter will need to be considered further by the local planning authority.

Notwithstanding the above, if you are minded to grant planning permission we request that the following **Conditions and Advisory Notes** are included within any subsequent consent.

### **Condition**

No surface water and/or land drainage shall be allowed to connect directly or indirectly with the public sewerage network.

**Reason:** To prevent hydraulic overloading of the public sewerage system, to protect the health and safety of existing residents and ensure no pollution of or detriment to the environment.

### **Advisory Notes**

*The applicant may need to apply to Dwr Cymru / Welsh Water for any connection to the public sewer under S106 of the Water Industry Act 1991. If the connection to the public sewer network is either via a lateral drain (i.e. a drain which extends beyond the connecting property boundary) or via a new sewer (i.e. serves more than one property), it is now a mandatory requirement to first enter into a Section 104 Adoption Agreement (Water Industry Act 1991). The design of the sewers and lateral drains must also conform to the Welsh Ministers Standards for Gravity Foul Sewers and Lateral Drains, and conform with the publication "Sewers for Adoption"- 7th Edition. Further information can be obtained via the Developer Services pages of [www.dwrcymru.com](http://www.dwrcymru.com).*

*The applicant is also advised that some public sewers and lateral drains may not be recorded on our maps of public sewers because they were originally privately owned and were transferred into public ownership by nature of the Water Industry (Schemes for Adoption of Private Sewers) Regulations 2011. The presence of such assets may affect the proposal. In order to assist us in dealing with the proposal the applicant may contact Dwr Cymru Welsh Water to establish the location and status of the apparatus. Under the Water Industry Act 1991 Dwr Cymru Welsh Water has rights of access to its apparatus at all times.*

*In accordance with Planning Policy Wales (Edition 12) and Technical Advice Note 12 (Design), the applicant is advised to take a sustainable approach in considering water supply in new development proposals, including utilising approaches that improve water efficiency and reduce water consumption. We would recommend that the applicant liaises with the relevant Local Authority Building Control department to discuss their water efficiency requirements.*

*As of 7th January 2019, this proposed development may be subject to Schedule 3 of the Flood and Water Management Act 2010. The development may therefore require approval of Sustainable Drainage Systems (SuDS) features, from the determining SuDS Approval Body (SAB), in accordance with the 'Statutory standards for sustainable drainage systems – designing, constructing, operating and maintaining surface water drainage systems'*



Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.  
Mae Dwr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in  
Welsh and English

Dŵr Cymru Cyf, a limited company registered in  
Wales no 2366777. Registered office: Pentwyn Road,  
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y  
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng  
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn  
Nelson, Treharris, Morgannwg Ganol CF46 6LY.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries, please contact the undersigned on 0800 917 2652 or via email at [developer.services@dwrcymru.com](mailto:developer.services@dwrcymru.com)

Please quote our reference number in all communications and correspondence.

Yours faithfully,

**Bethan Davies**  
**Development Planning Officer**  
**Developer Services**



Welsh Water is owned by Glas Cymru – a 'not-for-profit' company.  
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni 'nid-er-elw'.

We welcome correspondence in  
Welsh and English

Dŵr Cymru Cyf, a limited company registered in  
Wales no 2366777. Registered office: Pentwyn Road,  
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y  
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng  
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn  
Nelson, Treharris, Morgannwg Ganol CF46 6LY.