

INTERNAL MEMORANDUM

To: Caroline Pulley
From: Tom Bramley
Re: P/20/0096
Date: 15th June 2020

**RE: P/20/0096 | Interpretation panel | Land Adjacent To Lay-by On Road Between
Bedlinog And Fochriw, Gelligaer And Merthyr Common**

With regards to the above application I am in receipt of the detailed drawings for the construction element of the work. Please find the following observations:

The graphicly dimensioned proportions and the confirmation of the construction methods are deemed to be acceptable. It is recommended that the construction is seated on a concrete base which is finished 100 mm below the finished ground level. Such a construction method will provide a sound base which will not be visible within the local landscape. The base should be approximately 150mm depth. Arisings should be either disposed of off-site or graded and distributed evenly within the local environment.

Should you wish to discuss this matter further, then please do not hesitate to contact me.

Kind regards

Tom Bramley
Landscape Architect