

INTERNAL MEMORANDUM

To	Head of Planning	From	Head of Engineering
Ref	P / 20 / 0278	Ask For	Gerald Coughlan
Date	25th November 2020	Tel ext	6216

OBSERVATIONS BY THE ENGINEERING DEPARTMENT IN RESPECT OF

Applicant MKR Properties Ltd., Unit 1, Pontsarn Road, Merthyr Road, Merthyr Tydfil, CF48 2TN.

Location Land at Pant Industrial Estate Pant Mertyr Tydfil .

Detail Vary condition 8 (retaining walls) of planning permission P/20/0109

PLANNING NEED TO KNOW

OBSERVATIONS

I have no objection to the submitted proposals subject to the following conditions:-


CONDITIONS

Full details and calculations of any retaining walls exceeding 1 m in height are to be submitted to, and approved by, the LPA before their construction commences.

REASONS FOR CONDITIONS

REASONS FOR REFUSAL

INFORMATIVES



pp Carwyn Morris
Engineering & Traffic Group Leader .