


Project Pant Ind Est - RW around units 1 & 2				Job no. 311374	
Calcs for 1500 high RW				Start page no./Revision RW1500 1	
Calcs by AF	Calcs date 16/06/2023	Checked by AS	Checked date 19/06/2023	Approved by	Approved date

RETAINING WALL ANALYSIS (BS 8002:1994)

TEDDS calculation version 1.2.01.08



Wall details

Retaining wall type
Height of retaining wall stem
Thickness of wall stem
Length of toe
Length of heel
Overall length of base
Thickness of base
Depth of downstand
Position of downstand
Thickness of downstand
Height of retaining wall
Depth of cover in front of wall
Depth of unplanned excavation
Height of ground water behind wall
Height of saturated fill above base
Density of wall construction
Density of base construction
Angle of rear face of wall
Angle of soil surface behind wall
Effective height at virtual back of wall

Unpropped cantilever

$h_{\text{stem}} = 1500 \text{ mm}$
 $t_{\text{wall}} = 305 \text{ mm}$
 $l_{\text{toe}} = 900 \text{ mm}$
 $l_{\text{heel}} = 150 \text{ mm}$
 $l_{\text{base}} = l_{\text{toe}} + l_{\text{heel}} + t_{\text{wall}} = 1355 \text{ mm}$
 $t_{\text{base}} = 300 \text{ mm}$
 $d_{\text{ds}} = 0 \text{ mm}$
 $l_{\text{ds}} = 1005 \text{ mm}$
 $t_{\text{ds}} = 300 \text{ mm}$
 $h_{\text{wall}} = h_{\text{stem}} + t_{\text{base}} + d_{\text{ds}} = 1800 \text{ mm}$
 $d_{\text{cover}} = 600 \text{ mm}$
 $d_{\text{exc}} = 0 \text{ mm}$
 $h_{\text{water}} = 0 \text{ mm}$
 $h_{\text{sat}} = \max(h_{\text{water}} - t_{\text{base}} - d_{\text{ds}}, 0 \text{ mm}) = 0 \text{ mm}$
 $\gamma_{\text{wall}} = 23.6 \text{ kN/m}^3$
 $\gamma_{\text{base}} = 23.6 \text{ kN/m}^3$
 $\alpha = 90.0 \text{ deg}$
 $\beta = 0.0 \text{ deg}$
 $h_{\text{eff}} = h_{\text{wall}} + l_{\text{heel}} \times \tan(\beta) = 1800 \text{ mm}$

Retained material details

Mobilisation factor
Moist density of retained material

$M = 1.5$
 $\gamma_m = 21.0 \text{ kN/m}^3$

Project Pant Ind Est - RW around units 1 & 2				Job no. 311374	
Calcs for 1500 high RW				Start page no./Revision RW1500 2	
Calcs by AF	Calcs date 16/06/2023	Checked by AS	Checked date 19/06/2023	Approved by	Approved date

Saturated density of retained material

$$\gamma_s = 23.0 \text{ kN/m}^3$$

Design shear strength

$$\phi' = 22.6 \text{ deg}$$

Angle of wall friction

$$\delta = 17.3 \text{ deg}$$

Base material details

Moist density

$$\gamma_{mb} = 18.0 \text{ kN/m}^3$$

Design shear strength

$$\phi'_b = 24.2 \text{ deg}$$

Design base friction

$$\delta_b = 18.6 \text{ deg}$$

Allowable bearing pressure

$$P_{bearing} = 100 \text{ kN/m}^2$$

Using Rankine theory

Active pressure coefficient for retained material
($\cos(\phi')^2$)

$$K_a = (\cos(\beta) - \sqrt{[(\cos(\beta))^2 - (\cos(\phi'))^2]}) / (\cos(\beta) + \sqrt{[(\cos(\beta))^2 - (\cos(\phi'))^2]})$$

$$K_a = 0.445$$

Passive pressure coefficient for base material

$$K_p = (1 + \sqrt{[1 - (\cos(\phi'_b))^2]}) / (1 - \sqrt{[1 - (\cos(\phi'_b))^2]}) = 2.389$$

At-rest pressure

At-rest pressure for retained material

$$K_0 = 1 - \sin(\phi') = 0.616$$

Loading details

Surcharge load on plan

$$\text{Surcharge} = 12.5 \text{ kN/m}^2$$

Applied vertical dead load on wall

$$W_{dead} = 0.0 \text{ kN/m}$$

Applied vertical live load on wall

$$W_{live} = 0.0 \text{ kN/m}$$

Position of applied vertical load on wall

$$l_{load} = 0 \text{ mm}$$

Applied horizontal dead load on wall


$$F_{dead} = 0.0 \text{ kN/m}$$

Applied horizontal live load on wall

$$F_{live} = 0.0 \text{ kN/m}$$

Height of applied horizontal load on wall

$$h_{load} = 0 \text{ mm}$$



Loads shown in kN/m, pressures shown in kN/m²

Project Pant Ind Est - RW around units 1 & 2				Job no. 311374	
Calcs for 1500 high RW				Start page no./Revision RW1500 3	
Calcs by AF	Calcs date 16/06/2023	Checked by AS	Checked date 19/06/2023	Approved by	Approved date

Vertical forces on wall

Wall stem	$W_{wall} = h_{stem} \times t_{wall} \times \gamma_{wall} = \mathbf{10.8 \text{ kN/m}}$
Wall base	$W_{base} = l_{base} \times t_{base} \times \gamma_{base} = \mathbf{9.6 \text{ kN/m}}$
Surcharge	$W_{sur} = \text{Surcharge} \times l_{heel} = \mathbf{1.9 \text{ kN/m}}$
Moist backfill to top of wall	$W_{m_w} = l_{heel} \times (h_{stem} - h_{sat}) \times \gamma_m = \mathbf{4.7 \text{ kN/m}}$
Soil in front of wall	$W_p = l_{toe} \times d_{cover} \times \gamma_{mb} = \mathbf{9.7 \text{ kN/m}}$
Total vertical load	$W_{total} = W_{wall} + W_{base} + W_{sur} + W_{m_w} + W_p = \mathbf{36.7 \text{ kN/m}}$

Horizontal forces on wall

Surcharge	$F_{sur} = K_a \times \text{Surcharge} \times h_{eff} = \mathbf{10 \text{ kN/m}}$
Moist backfill above water table	$F_{m_a} = 0.5 \times K_a \times \gamma_m \times (h_{eff} - h_{water})^2 = \mathbf{15.1 \text{ kN/m}}$
Total horizontal load	$F_{total} = F_{sur} + F_{m_a} = \mathbf{25.1 \text{ kN/m}}$

Calculate stability against sliding

Passive resistance of soil in front of wall	$F_p = 0.5 \times K_p \times (d_{cover} + t_{base} + d_{ds} - d_{exc})^2 \times \gamma_{mb} = \mathbf{17.4 \text{ kN/m}}$
Resistance to sliding	$F_{res} = F_p + (W_{total} - W_{sur} - W_p) \times \tan(\delta_b) = \mathbf{25.9 \text{ kN/m}}$
<i>PASS - Resistance force is greater than sliding force</i>	

Overturning moments

Surcharge	$M_{sur} = F_{sur} \times (h_{eff} - 2 \times d_{ds}) / 2 = \mathbf{9 \text{ kNm/m}}$
Moist backfill above water table	$M_{m_a} = F_{m_a} \times (h_{eff} + 2 \times h_{water} - 3 \times d_{ds}) / 3 = \mathbf{9.1 \text{ kNm/m}}$
Total overturning moment	$M_{ot} = M_{sur} + M_{m_a} = \mathbf{18.1 \text{ kNm/m}}$

Restoring moments

Wall stem	$M_{wall} = W_{wall} \times (l_{toe} + t_{wall} / 2) = \mathbf{11.4 \text{ kNm/m}}$
Wall base	$M_{base} = W_{base} \times l_{base} / 2 = \mathbf{6.5 \text{ kNm/m}}$
Moist backfill	$M_{m_r} = (W_{m_w} \times (l_{base} - l_{heel} / 2) + W_{m_s} \times (l_{base} - l_{heel} / 3)) = \mathbf{6 \text{ kNm/m}}$
Total restoring moment	$M_{rest} = M_{wall} + M_{base} + M_{m_r} = \mathbf{23.9 \text{ kNm/m}}$

Check stability against overturning

Total overturning moment	$M_{ot} = \mathbf{18.1 \text{ kNm/m}}$
Total restoring moment	$M_{rest} = \mathbf{23.9 \text{ kNm/m}}$
<i>PASS - Restoring moment is greater than overturning moment</i>	

Check bearing pressure

Surcharge	$M_{sur_r} = W_{sur} \times (l_{base} - l_{heel} / 2) = \mathbf{2.4 \text{ kNm/m}}$
Soil in front of wall	$M_{p_r} = W_p \times l_{toe} / 2 = \mathbf{4.4 \text{ kNm/m}}$
Total moment for bearing	$M_{total} = M_{rest} - M_{ot} + M_{sur_r} + M_{p_r} = \mathbf{12.6 \text{ kNm/m}}$
Total vertical reaction	$R = W_{total} = \mathbf{36.7 \text{ kN/m}}$
Distance to reaction	$X_{bar} = M_{total} / R = \mathbf{343 \text{ mm}}$
Eccentricity of reaction	$e = \text{abs}((l_{base} / 2) - X_{bar}) = \mathbf{334 \text{ mm}}$
<i>Reaction acts outside middle third of base</i>	
Bearing pressure at toe	$p_{toe} = R / (1.5 \times X_{bar}) = \mathbf{71.3 \text{ kN/m}^2}$
Bearing pressure at heel	$p_{heel} = 0 \text{ kN/m}^2 = \mathbf{0 \text{ kN/m}^2}$
<i>PASS - Maximum bearing pressure is less than allowable bearing pressure</i>	



Project Pant Ind Est - RW around units 1 & 2				Job no. 311374	
Calcs for 1500 high RW				Start page no./Revision RW1500 4	
Calcs by AF	Calcs date 16/06/2023	Checked by AS	Checked date 19/06/2023	Approved by	Approved date

RETAINING WALL DESIGN (BS 8002:1994)

TEDDS calculation version 1.2.01.08

Ultimate limit state load factors

Dead load factor	$\gamma_{f,d} = 1.4$
Live load factor	$\gamma_{f,l} = 1.6$
Earth and water pressure factor	$\gamma_{f,e} = 1.4$

Factored vertical forces on wall

Wall stem	$W_{wall,f} = \gamma_{f,d} \times h_{stem} \times t_{wall} \times \gamma_{wall} = 15.1 \text{ kN/m}$
Wall base	$W_{base,f} = \gamma_{f,d} \times l_{base} \times t_{base} \times \gamma_{base} = 13.4 \text{ kN/m}$
Surcharge	$W_{sur,f} = \gamma_{f,l} \times \text{Surcharge} \times l_{heel} = 3 \text{ kN/m}$
Moist backfill to top of wall	$W_{m,w,f} = \gamma_{f,d} \times l_{heel} \times (h_{stem} - h_{sat}) \times \gamma_m = 6.6 \text{ kN/m}$
Soil in front of wall	$W_{p,f} = \gamma_{f,d} \times l_{toe} \times d_{cover} \times \gamma_{mb} = 13.6 \text{ kN/m}$
Total vertical load	$W_{total,f} = W_{wall,f} + W_{base,f} + W_{sur,f} + W_{m,w,f} + W_{p,f} = 51.8 \text{ kN/m}$

Factored horizontal at-rest forces on wall

Surcharge	$F_{sur,f} = \gamma_{f,l} \times K_0 \times \text{Surcharge} \times h_{eff} = 22.2 \text{ kN/m}$
Moist backfill above water table	$F_{m,a,f} = \gamma_{f,e} \times 0.5 \times K_0 \times \gamma_m \times (h_{eff} - h_{water})^2 = 29.3 \text{ kN/m}$
Total horizontal load	$F_{total,f} = F_{sur,f} + F_{m,a,f} = 51.5 \text{ kN/m}$
Passive resistance of soil in front of wall	$F_{p,f} = \gamma_{f,e} \times 0.5 \times K_p \times (d_{cover} + t_{base} + d_{ds} - d_{exc})^2 \times \gamma_{mb} = 24.4 \text{ kN/m}$

Factored overturning moments

Surcharge	$M_{sur,f} = F_{sur,f} \times (h_{eff} - 2 \times d_{ds}) / 2 = 19.9 \text{ kNm/m}$
Moist backfill above water table	$M_{m,a,f} = F_{m,a,f} \times (h_{eff} + 2 \times h_{water} - 3 \times d_{ds}) / 3 = 17.6 \text{ kNm/m}$
Total overturning moment	$M_{ot,f} = M_{sur,f} + M_{m,a,f} = 37.5 \text{ kNm/m}$

Restoring moments

Wall stem	$M_{wall,f} = W_{wall,f} \times (l_{toe} + t_{wall} / 2) = 15.9 \text{ kNm/m}$
Wall base	$M_{base,f} = W_{base,f} \times l_{base} / 2 = 9.1 \text{ kNm/m}$
Surcharge	$M_{sur,r,f} = W_{sur,f} \times (l_{base} - l_{heel} / 2) = 3.8 \text{ kNm/m}$
Moist backfill	$M_{m,r,f} = (W_{m,w,f} \times (l_{base} - l_{heel} / 2) + W_{m,s,f} \times (l_{base} - l_{heel} / 3)) = 8.5 \text{ kNm/m}$
Soil in front of wall	$M_{p,r,f} = W_{p,f} \times l_{toe} / 2 = 6.1 \text{ kNm/m}$
Total restoring moment	$M_{rest,f} = M_{wall,f} + M_{base,f} + M_{sur,r,f} + M_{m,r,f} + M_{p,r,f} = 43.4 \text{ kNm/m}$

Factored bearing pressure

Total moment for bearing	$M_{total,f} = M_{rest,f} - M_{ot,f} = 5.9 \text{ kNm/m}$
Total vertical reaction	$R_f = W_{total,f} = 51.8 \text{ kN/m}$
Distance to reaction	$X_{bar,f} = M_{total,f} / R_f = 114 \text{ mm}$
Eccentricity of reaction	$e_f = \text{abs}((l_{base} / 2) - X_{bar,f}) = 564 \text{ mm}$ <i>Reaction acts outside middle third of base</i>
Bearing pressure at toe	$p_{toe,f} = R_f / (1.5 \times X_{bar,f}) = 303 \text{ kN/m}^2$
Bearing pressure at heel	$p_{heel,f} = 0 \text{ kN/m}^2 = 0 \text{ kN/m}^2$
Rate of change of base reaction	$\text{rate} = p_{toe,f} / (3 \times X_{bar,f}) = 887.00 \text{ kN/m}^2/\text{m}$
Bearing pressure at stem / toe	$p_{stem_toe,f} = \text{max}(p_{toe,f} - (\text{rate} \times l_{toe}), 0 \text{ kN/m}^2) = 0 \text{ kN/m}^2$
Bearing pressure at mid stem	$p_{stem_mid,f} = \text{max}(p_{toe,f} - (\text{rate} \times (l_{toe} + t_{wall} / 2)), 0 \text{ kN/m}^2) = 0 \text{ kN/m}^2$
Bearing pressure at stem / heel	$p_{stem_heel,f} = \text{max}(p_{toe,f} - (\text{rate} \times (l_{toe} + t_{wall})), 0 \text{ kN/m}^2) = 0 \text{ kN/m}^2$

Design of reinforced concrete retaining wall toe (BS 8002:1994)

Project Pant Ind Est - RW around units 1 & 2				Job no. 311374	
Calcs for 1500 high RW				Start page no./Revision RW1500 5	
Calcs by AF	Calcs date 16/06/2023	Checked by AS	Checked date 19/06/2023	Approved by	Approved date

Material properties

Characteristic strength of concrete
Characteristic strength of reinforcement

$$f_{cu} = 35 \text{ N/mm}^2$$

$$f_y = 500 \text{ N/mm}^2$$

Base details

Minimum area of reinforcement
Cover to reinforcement in toe

$$k = 0.13 \%$$

$$C_{toe} = 50 \text{ mm}$$

Calculate shear for toe design

Shear from bearing pressure
Shear from weight of base
Shear from weight of soil
Total shear for toe design

$$V_{toe_bear} = 3 \times p_{toe_f} \times X_{bar_f} / 2 = 51.8 \text{ kN/m}$$

$$V_{toe_wt_base} = \gamma_{f_d} \times \gamma_{base} \times l_{toe} \times t_{base} = 8.9 \text{ kN/m}$$

$$V_{toe_wt_soil} = W_{p_f} - (\gamma_{f_d} \times \gamma_m \times l_{toe} \times d_{exc}) = 13.6 \text{ kN/m}$$

$$V_{toe} = V_{toe_bear} - V_{toe_wt_base} - V_{toe_wt_soil} = 29.2 \text{ kN/m}$$

Calculate moment for toe design


Moment from bearing pressure
Moment from weight of base
Moment from weight of soil
Total moment for toe design

$$M_{toe_bear} = 3 \times p_{toe_f} \times X_{bar_f} \times (l_{toe} - X_{bar_f} + t_{wall} / 2) / 2 = 48.6 \text{ kNm/m}$$

$$M_{toe_wt_base} = (\gamma_{f_d} \times \gamma_{base} \times t_{base} \times (l_{toe} + t_{wall} / 2)^2 / 2) = 5.5 \text{ kNm/m}$$

$$M_{toe_wt_soil} = (W_{p_f} - (\gamma_{f_d} \times \gamma_m \times l_{toe} \times d_{exc})) \times (l_{toe} + t_{wall} / 2) / 2 = 8.2 \text{ kNm/m}$$

$$M_{toe} = M_{toe_bear} - M_{toe_wt_base} - M_{toe_wt_soil} = 34.9 \text{ kNm/m}$$



Check toe in bending

Width of toe
Depth of reinforcement
Constant

$$b = 1000 \text{ mm/m}$$

$$d_{toe} = t_{base} - C_{toe} - (\phi_{toe} / 2) = 245.0 \text{ mm}$$

$$K_{toe} = M_{toe} / (b \times d_{toe}^2 \times f_{cu}) = 0.017$$

Compression reinforcement is not required

Lever arm

$$Z_{toe} = \min(0.5 + \sqrt{(0.25 - (\min(K_{toe}, 0.225) / 0.9))}, 0.95) \times d_{toe}$$

$$Z_{toe} = 233 \text{ mm}$$

Area of tension reinforcement required
Minimum area of tension reinforcement
Area of tension reinforcement required
Reinforcement provided
Area of reinforcement provided

$$A_{s_toe_des} = M_{toe} / (0.87 \times f_y \times Z_{toe}) = 345 \text{ mm}^2/\text{m}$$

$$A_{s_toe_min} = k \times b \times t_{base} = 390 \text{ mm}^2/\text{m}$$

$$A_{s_toe_req} = \text{Max}(A_{s_toe_des}, A_{s_toe_min}) = 390 \text{ mm}^2/\text{m}$$

A393 mesh

$$A_{s_toe_prov} = 393 \text{ mm}^2/\text{m}$$

PASS - Reinforcement provided at the retaining wall toe is adequate

Check shear resistance at toe

Design shear stress
Allowable shear stress

$$v_{toe} = V_{toe} / (b \times d_{toe}) = 0.119 \text{ N/mm}^2$$

$$v_{adm} = \min(0.8 \times \sqrt{f_{cu}} / 1 \text{ N/mm}^2, 5) \times 1 \text{ N/mm}^2 = 4.733 \text{ N/mm}^2$$

PASS - Design shear stress is less than maximum shear stress

From BS8110:Part 1:1997 – Table 3.8

Design concrete shear stress

$$v_{c_toe} = 0.434 \text{ N/mm}^2$$

Project Pant Ind Est - RW around units 1 & 2				Job no. 311374	
Calcs for 1500 high RW				Start page no./Revision RW1500 6	
Calcs by AF	Calcs date 16/06/2023	Checked by AS	Checked date 19/06/2023	Approved by	Approved date

$V_{toe} < V_{c_toe}$ - No shear reinforcement required

Design of reinforced concrete retaining wall heel (BS 8002:1994)

Material properties

Characteristic strength of concrete $f_{cu} = 35 \text{ N/mm}^2$
 Characteristic strength of reinforcement $f_y = 500 \text{ N/mm}^2$

Base details


Minimum area of reinforcement $k = 0.13 \%$
 Cover to reinforcement in heel $C_{heel} = 50 \text{ mm}$

Calculate shear for heel design

Shear from weight of base $V_{heel_wt_base} = \gamma_{fd} \times \gamma_{base} \times l_{heel} \times t_{base} = 1.5 \text{ kN/m}$
 Shear from weight of moist backfill $V_{heel_wt_m} = W_{m_w_f} = 6.6 \text{ kN/m}$
 Shear from surcharge $V_{heel_sur} = W_{sur_f} = 3 \text{ kN/m}$
 Total shear for heel design $V_{heel} = V_{heel_wt_base} + V_{heel_wt_m} + V_{heel_sur} = 11.1 \text{ kN/m}$

Calculate moment for heel design

Moment from weight of base $M_{heel_wt_base} = (\gamma_{fd} \times \gamma_{base} \times t_{base} \times (l_{heel} + t_{wall} / 2)^2 / 2) = 0.5 \text{ kNm/m}$
 Moment from weight of moist backfill $M_{heel_wt_m} = W_{m_w_f} \times (l_{heel} + t_{wall}) / 2 = 1.5 \text{ kNm/m}$
 Moment from surcharge $M_{heel_sur} = W_{sur_f} \times (l_{heel} + t_{wall}) / 2 = 0.7 \text{ kNm/m}$
 Total moment for heel design $M_{heel} = M_{heel_wt_base} + M_{heel_wt_m} + M_{heel_sur} = 2.6 \text{ kNm/m}$



Check heel in bending

Width of heel $b = 1000 \text{ mm/m}$
 Depth of reinforcement $d_{heel} = t_{base} - C_{heel} - (\phi_{heel} / 2) = 245.0 \text{ mm}$
 Constant $K_{heel} = M_{heel} / (b \times d_{heel}^2 \times f_{cu}) = 0.001$
 Compression reinforcement is not required
 Lever arm $Z_{heel} = \min(0.5 + \sqrt{(0.25 - (\min(K_{heel}, 0.225) / 0.9))}, 0.95) \times d_{heel}$
 $Z_{heel} = 233 \text{ mm}$
 Area of tension reinforcement required $A_{s_heel_des} = M_{heel} / (0.87 \times f_y \times Z_{heel}) = 26 \text{ mm}^2/\text{m}$
 Minimum area of tension reinforcement $A_{s_heel_min} = k \times b \times t_{base} = 390 \text{ mm}^2/\text{m}$
 Area of tension reinforcement required $A_{s_heel_req} = \max(A_{s_heel_des}, A_{s_heel_min}) = 390 \text{ mm}^2/\text{m}$
 Reinforcement provided **A393 mesh**
 Area of reinforcement provided $A_{s_heel_prov} = 393 \text{ mm}^2/\text{m}$
PASS - Reinforcement provided at the retaining wall heel is adequate

Check shear resistance at heel

Design shear stress $v_{heel} = V_{heel} / (b \times d_{heel}) = 0.045 \text{ N/mm}^2$
 Allowable shear stress $v_{adm} = \min(0.8 \times \sqrt{f_{cu} / 1 \text{ N/mm}^2}, 5) \times 1 \text{ N/mm}^2 = 4.733 \text{ N/mm}^2$
PASS - Design shear stress is less than maximum shear stress

Project Pant Ind Est - RW around units 1 & 2				Job no. 311374	
Calcs for 1500 high RW				Start page no./Revision RW1500 7	
Calcs by AF	Calcs date 16/06/2023	Checked by AS	Checked date 19/06/2023	Approved by	Approved date


From BS8110:Part 1:1997 – Table 3.8

Design concrete shear stress

$$V_{c_heel} = 0.434 \text{ N/mm}^2$$

$V_{heel} < V_{c_heel}$ - No shear reinforcement required

Design of cavity reinforced masonry retaining wall stem - BS5628-2:2000



Wall details

Thickness of outer leaf of wall

$$t_{outer} = 103 \text{ mm}$$

Thickness of inner leaf of wall

$$t_{inner} = 103 \text{ mm}$$

Thickness of reinforced cavity

$$t_{cavity} = t_{wall} - t_{outer} - t_{inner} = 100 \text{ mm}$$

Depth of stem reinforcement

$$d_{stem} = 178 \text{ mm}$$

Masonry details

Masonry type

Standard format bricks

Compressive strength of units

$$p_{unit} = 30.0 \text{ N/mm}^2$$

Mortar designation

(ii)

Category of manufacturing control of units

Category II

Partial safety factor for material strength

$$\gamma_{mm} = 2.3$$

Characteristic compressive strength of masonry

From BS5628:2 Table 3a, mortar ii

Characteristic compressive strength

$$f_k = 7.1 \text{ N/mm}^2$$

Factored horizontal at-rest forces on stem

Surcharge

$$F_{s_sur_f} = \gamma_{f_l} \times K_0 \times \text{Surcharge} \times (h_{eff} - t_{base} - d_{ds}) = 18.5 \text{ kN/m}$$

Moist backfill above water table

$$F_{s_m_a_f} = 0.5 \times \gamma_{f_e} \times K_0 \times \gamma_m \times (h_{eff} - t_{base} - d_{ds} - h_{sat})^2 = 20.4 \text{ kN/m}$$

Calculate shear for stem design

Shear at base of stem

$$V_{stem} = F_{s_sur_f} + F_{s_m_a_f} = 38.8 \text{ kN/m}$$

Calculate moment for stem design

Surcharge

$$M_{s_sur} = F_{s_sur_f} \times (h_{stem} + t_{base}) / 2 = 16.6 \text{ kNm/m}$$

Moist backfill above water table

$$M_{s_m_a} = F_{s_m_a_f} \times (2 \times h_{sat} + h_{eff} - d_{ds} + t_{base} / 2) / 3 = 13.2 \text{ kNm/m}$$

Total moment for stem design

$$M_{stem} = M_{s_sur} + M_{s_m_a} = 29.9 \text{ kNm/m}$$

Check maximum design moment for wall stem

Width of wall

$$b = 1000 \text{ mm/m}$$

Maximum design moment

$$M_{d_stem} = 0.4 \times f_k \times b \times d_{stem}^2 / \gamma_{mm} = 38.9 \text{ kNm/m}$$

PASS - Applied moment is less than maximum design moment

Check wall stem in bending

Moment of resistance factor

$$Q = M_{stem} / d_{stem}^2 = 0.948 \text{ N/mm}^2$$

$$Q = 2 \times c \times (1 - c) \times f_k / \gamma_{mm}$$

Project Pant Ind Est - RW around units 1 & 2				Job no. 311374	
Calcs for 1500 high RW				Start page no./Revision RW1500 8	
Calcs by AF	Calcs date 16/06/2023	Checked by AS	Checked date 19/06/2023	Approved by	Approved date

Lever arm factor

$$c = \mathbf{0.811}$$

Lever arm

$$Z_{stem} = \min(0.95, c) \times d_{stem} = \mathbf{143.9 \text{ mm}}$$

Area of tension reinforcement required

$$A_{s_stem_des} = M_{stem} \times \gamma_{ms} / (f_y \times Z_{stem}) = \mathbf{477 \text{ mm}^2/\text{m}}$$

Minimum area of tension reinforcement

$$A_{s_stem_min} = k \times b \times t_{wall} = \mathbf{397 \text{ mm}^2/\text{m}}$$

Area of tension reinforcement required

$$A_{s_stem_req} = \text{Max}(A_{s_stem_des}, A_{s_stem_min}) = \mathbf{477 \text{ mm}^2/\text{m}}$$

Reinforcement provided

B503 mesh

Area of reinforcement provided

$$A_{s_stem_prov} = \pi \times \phi_{stem}^2 / (4 \times S_{stem}) = \mathbf{503 \text{ mm}^2/\text{m}}$$

PASS - Reinforcement provided at the retaining wall stem is adequate

Check shear resistance at wall stem

Design shear stress

$$V_{stem} = V_{stem} / (b \times d_{stem}) = \mathbf{0.219 \text{ N/mm}^2}$$

Basic characteristic shear strength of masonry

$$f_{vbas} = \min[0.35 + (17.5 \times A_{s_stem_prov} / (b \times d_{stem})), 0.7] \times 1 \text{ N/mm}^2$$

$$f_{vbas} = \mathbf{0.400 \text{ N/mm}^2}$$

Shear span

$$a = M_{stem} / V_{stem} = \mathbf{768.9 \text{ mm}}$$

Characteristic shear strength of masonry

$$f_v = \text{Min}(f_{vbas} \times \max(2.5 - 0.25 \times (a / d_{stem}), 1), 1.75 \text{ N/mm}^2)$$

$$f_v = \mathbf{0.566 \text{ N/mm}^2}$$

Allowable shear stress

$$V_{adm} = f_v / \gamma_{mv} = \mathbf{0.283 \text{ N/mm}^2}$$

PASS - Design shear stress is less than maximum shear stress

Check limiting dimensions

Limiting span/effective depth ratio

$$\text{ratio}_{max} = \mathbf{18.00}$$

Actual span/effective depth ratio

$$\text{ratio}_{act} = (h_{stem} + d_{stem} / 2) / d_{stem} = \mathbf{8.95}$$

PASS - Span to depth ratio is acceptable

Axial load check

Factored axial load on wall

$$N_{wall} = ([t_{wall} \times h_{stem} \times \gamma_{wall} + W_{dead}] \times \gamma_{f_d}) + (W_{live} \times \gamma_{f_l}) = \mathbf{15.1 \text{ kN/m}}$$


Limiting axial load

$$N_{limit} = 0.1 \times f_k \times t_{wall} = \mathbf{216.6 \text{ kN/m}}$$

Applied axial load may be ignored - calculations valid

Project				Job no.	
Pant Ind Est - RW around units 1 & 2				311374	
Calcs for				Start page no./Revision	
1500 high RW				RW1500 9	
Calcs by	Calcs date	Checked by	Checked date	Approved by	Approved date
AF	16/06/2023	AS	19/06/2023		

Indicative retaining wall reinforcement diagram



Toe mesh - A393 - (393 mm²/m)
 Heel mesh - A393 - (393 mm²/m)
 Stem mesh - B503 - (503 mm²/m)