

- Indicates 1no. layer of 25mm Isover Acoustic Partition Roll (APR 1200) insulation batts installed to all walls between sanitary accommodation and a habitable room, and between any bedroom and a habitable room.
- Denotes 12mm OSB batts to walls within Kitchens, fitted between studs at a height of 800mm and 1100mm above finished floor level for kitchen base units and 1650mm and 2250mm above finished floor level for kitchen wall units.
- Additional localised 12mm OSB pattresses are to be installed wherever sanitaryware, wall cupboards, boiler units and radiators are also fixed to stud walls.
- Positions to be agreed on-site.
- Loft space to have min. 89q.m. of moisture resistant flooring grade chipboard laid on top of joist structure on ceilings joists to maintain min. 400mm deep void between u/s of floor and top of ceiling to accommodate ceiling insulation. Light fitting connected to neon indicator switch on first floor landing.



Ref.	Structural Opening	Leaf	Clear Opening	Comments
	Width	Height	Width	
D1	1000	2110	936	2040 44 872 Min. clear opening required 775mm.
D2	1000	2110	926	2040 44 872 Min. clear opening required 775mm.
D3	1000	2110	926	2040 44 872 Min. clear opening required 750mm.
D4	700	2110	626	2040 44 552 Min. opening N/A as St door.
D5	1000	2110	926	2040 44 872 Min. clear opening required 775mm.
D7	1130	2110	956*	2040 44 968 Min. opening N/A as St door. Pair of double doors.
D8	1000	2110	926	2040 44 872 Min. clear opening required 750mm.
D9	700	2110	626	2040 44 552 Min. opening N/A as St door.

FOR APPROVAL

pentan
architects

22 Cathedral Road
Cardiff CF11 9LJ
t. 029 2030 9010
info@pentan.co.uk

2B4P House (Plots 13 & 14) Plans, Elevations & Schedules

Job no.	Orig.	Zone	Level	Type	Role	Description	Status	Rev.
3831	- PEN	- ZZ	- ZZ	- DR	- A	- 0401	S3	P3
Scale							Date	
As indicated @ A1							Jan' 20	

NOTES Do not scale. All dimensions are in millimetres unless stated otherwise