

Merthyr Tydfil County Council
The Planning Division
Unit 5 Triangle Business Park
PENTREBACH
Merthyr Tydfil, Mid Glamorgan
CF48 4TQ

Date: 06/08/2025
Our Ref: PLA0088927
Your Ref: P/25/0196

Dear Sir/Madam,

Grid Ref: SO004073 300533 207428

Site: Jah Jireh Care Home, Heads Of The Valleys Road, Merthyr Tydfil

Development: Conversion of existing internal space to provide five new accommodation units within the existing building

We refer to your planning consultation relating to the above site, and we can provide the following comments in respect to the proposed development.

ASSET PROTECTION

The proposed development is crossed by a trunk/distribution watermain, the approximate position being shown on the attached plan. Dwr Cymru Welsh Water as Statutory Undertaker has statutory powers to access our apparatus at all times. I enclose our Conditions for Development near Watermain(s). It may be possible for this watermain to be diverted under Section 185 of the Water Industry Act 1991, the cost of which will be re-charged to the developer. The developer must consult Dwr Cymru Welsh Water before any development commences on site.

SEWERAGE

We note from the application that the proposed development does not intend to connect to the public sewer network. As the sewerage undertaker we have no further comments to make. However, we recommend that a drainage strategy for the site be appropriately conditioned, implemented in full and retained for the lifetime of the development.

Should circumstances change and a connection to the public sewerage system/public sewage treatment works is preferred we must be re-consulted on this application.

WATER

We anticipate this development will require the installation of a new single water connection to serve the new premise. Capacity is available in the water supply system to accommodate the development. The applicant will need to apply to Dwr Cymru Welsh Water for a connection to the potable water supply system under Section 45 of the Water industry Act 1991. The applicant attention is drawn to our new water connection application guidance notes available on our website. DCWW is not responsible for fire protection or for providing suitable fire flows.

Our response is based on the information provided by your application. Should the proposal alter during the course of the application process we kindly request that we are re-consulted and reserve the right to make new representation.

If you have any queries please contact the undersigned on 0800 917 2652 or via email at developer.services@dwrcymru.com

Please quote our reference number in all communications and correspondence.

Yours faithfully,

Matthew Lord
Development Planning Officer
Developer Services



Welsh Water is owned by Glas Cymru – a ‘not-for-profit’ company.
Mae Dŵr Cymru yn eiddo i Glas Cymru – cwmni ‘nid-er-elw’.

We welcome correspondence in
Welsh and English

Dŵr Cymru Cyf, a limited company registered in
Wales no 2366777. Registered office: Pentwyn Road,
Nelson, Treharris, Mid Glamorgan CF46 6LY

Rydym yn croesawu gohebiaeth yn y
Gymraeg neu yn Saesneg

Dŵr Cymru Cyf, cwmni cyfyngedig wedi'i gofrestru yng
Nghymru rhif 2366777. Swyddfa gofrestredig: Heol Pentwyn
Nelson, Treharris, Morgannwg Ganol CF46 6LY.